

Trees to be removed.

Hedges to be removed.

Grade A - High quality trees to be retained

Grade B - Moderate quality trees to be retained

Grade C - Low quality trees to be retained

Hedges to be retained

New tree planting

New hedge planting

Root Protection Zone

Protective Herras fencing to trees and Euromesh fencing to hedgerows during construction.

Signage to protective fencing.
'KEEP OUT' Protection areas
to be kept free from construction
work, fire and storage of materials.

Stone drainage trench - below ground
300mm w x 600mm deep.
See Sumner Consultants Drawings

notes:

- All dimensions to be checked and confirmed onsite prior to any works.
- Do not scale off this drawing.
- Any errors, omissions or discrepancies are to be brought to the attention of Lingard Farrow Styles immediately.

BS 5837:2012

Root Protection Area fencing:

BRITISH STANDARD

Figure 3 Examples of above-ground stabilizing systems

a) Stabilizer strut with base plate secured with ground pins

6.2.3 Ground protection during demolition and construction

justified within the RPA, this should be facilitated by a set-back in the alignment of the tree protection barrier. In such areas, suitable existing hard surfacing that is not proposed for re-use as part of the finished design should be retained to act as temporary ground protection during construction, rather than being removed during demolition. The suitability of such surfacing for this purpose should be evaluated by the project arboriculturist and an engineer as appropriate.

© The British Standards Institution 2012 • 21

2009 Surve

2009 Survey Area

2009 Survey Area

Stump to be

Coach Park - Gravel / stone / earth

Bodpave Detail - where parking bays cover RPAs

NOT FOR CONSTRUCTION

BodPave®85 Paving Grids For Gravel Surfaces Design and Specification Guide

title:

Trees for Removal and Tree Protection Plan

dwg. no:	scale:	drawn:	chkd by:
2973-009 B	1:250@A1	thf	ps

DO NOT SCALE FROM DRAWING. © DRAWING IS COPYRIGHT