

MEMORANDUM



From: Ian Jones Public Protection
Service Manager

To: David Williams Planning
Control Manager

Our Ref:

Your Ref: P/2019/0299

Date: 25-04-2019

Town and Country Planning Act 1990

Town and Country Planning (General Development Procedure) Order 1996

Re: P/2019/0299, GLAS ABER LLANARMON DYFFRYN CEIRIOG LLANGOLLEN WREXHAM

APPLICATION FOR PRIOR NOTIFICATION OF PROPOSED INSTALLATION OF 15.0M HIGH LATTICE MAST ON A CONCRETE BASE ACCOMMODATING 3 NO. ANTENNAS AND 2 NO. TRANSMISSION DISHES TOGETHER WITH THE INSTALLATION OF 1 NO. FOUL WEATHER ENCLOSURE, 1 NO ELECTRICAL METER CABINET, 1 NO. GENERATOR AND 1 NO. POLE MOUNTED SATELLITE DISH WITHIN A COMPOUND SURROUNDED BY A 1.8M HIGH MESH FENCE

Environmental Protection - No Comments

The Public Protection Department has no objections to the proposed development provided that the Application is submitted with a Declaration of Conformance to ICNIRP Public Exposure Guidelines

ZP05 - NOISE GENERATION - BS4142 REQUIRED

The rating level of any noise generated by reason of this development shall not exceed the pre-existing background level by more than 5dB(A) at any time. The noise levels shall be determined at nearby noise sensitive premises, and measurements and assessment shall be made in accordance with BS4142:2014 Methods for rating and assessing industrial and commercial sound.

.....

Head of Planning and Environment