

FAO Philip Forster

06/03/2019

Dear Philip,

TOWN AND COUNTRY PLANNING ACT 1990
DEDDF CYNLLUNIO GWLAD A THREF 1990

**BWRIAD / PROPOSAL:
OUTLINE APPLICATION FOR THE ERECTION OF 1 NO. DWELLING (WITH ALL
MATTERS RESERVED)
LLEOLIAD / LOCATION:**

Land Adj. to 22 Park Road, Newbridge, Wrexham

Thank you for consulting Natural Resources Wales (NRW) about the above, which was received on 19/02/2019.

NRW has no objection to the proposal. However, we would provide the following advice:

Foul Drainage

No information has been provided regarding the disposal of foul waters from the proposed development. We refer you to WG Circular 008/2018 on private drainage, and specifically paragraphs 2.3-2.5, which stress the first presumption must be to provide a system of foul drainage discharging into a public sewer. We advise you the proposed development is in a publicly sewered area.

Please consult us again if foul sewage from the proposed development is to be disposed of by a non-mains drainage system.

Protected Sites

From the information provided, we consider that the proposal is not likely to have a significant effect on a SAC, SPA or Ramsar.

The site is located approximately 90m away from the River Dee and Bala Lake SAC however there are no potential impact pathways to features of this site:

Our advice may change should modifications be made to the proposed development prior to the determination of the application. If there are any changes to the proposed development which may affect the consideration of potential environmental impacts, please consult us again before you determine the application.

Protected Species

We note that there is no information about protected species with the application and, therefore, are assuming that your Authority has screened the application and concluded that there is not a reasonable likelihood of protected species being present.

Please do not hesitate to contact us if you require further information or clarification on any of the above.

Our comments above only relate specifically to matters that are listed in our 'Consultation Topics' document (September 2018) which is published on our website: (<https://cdn.naturalresources.wales/media/686847/dpas-consultation-topics-august-2018-eng.pdf?mode=pad&rnd=131819256840000000>). We have not considered potential effects on other matters and do not rule out the potential for the proposed development to affect other interests, including environmental interests of local importance.

Advice to Applicant

Pollution Prevention

All works at the site must be carried out in accordance with PPG6: 'Working at construction and demolition sites' which are available on the following website:

<http://www.netregs.org.uk/environmental-topics/pollution-prevention-guidelines-ppgs-and-replacement-series/guidance-for-pollution-prevention-gpps-full-list/>

Waste

Waste produced during the construction phase of your development must be dealt with appropriately and be in line with all relevant waste legislation including Duty of Care Regulations and Hazardous Waste Regulations. As part of your waste duty of care you must classify the waste produced:

- before it is collected, disposed of or recovered
- to identify the controls that apply to the movement of the waste
- to complete waste documents and records
- to identify suitably authorised waste management options
- to prevent harm to people and the environment.

Any waste removed from site will be subject to waste management controls. The links below provided information on how to classify waste and register as a waste carrier or hazardous waste producer:

<http://naturalresources.wales/waste/how-to-classify-and-assess-waste/?lang=en>

<http://naturalresources.wales/apply-for-a-permit/waste/?lang=en>

Further guidance can be found on the GOV website here:

<https://www.gov.uk/managing-your-waste-an-overview/duty-of-care>

Site Drainage

The proposed development is in an area of bedrock aquifer. This designation is consistent with the Water Framework Directive and reflects the importance of aquifers in terms of groundwater as a resource (drinking water supply) and also their role in supporting surface water flows and wetland ecosystems.

In the event that surface water from the development discharges to ground, we refer the developer to the Groundwater Protection: Principles and Practice (Environment Agency, 2013) Position Statements. We refer the developer to the Environment Agency 'Approach to groundwater protection' position statements which have been adopted by Natural Resources Wales. In particular the developer should be aware of the advice under Position Statements G13 (sustainable drainage systems) which applies to this development: (https://www.gov.uk/government/uploads/system/uploads/attachment_data/file/658135/LIT_7660.pdf)

The applicant should be advised that, in addition to planning permission, it is their responsibility to ensure that they secure all other permits/consents relevant to their development.

Yn gywir / Yours sincerely,

Daniel Davies

Daniel Davies

Cynghorydd Cynllunio Datblygu / Development Planning Advisor

Cyfoeth Naturiol Cymru / Natural Resources Wales