

MEMORANDUM

From: Ian Jones Public Protection
Service Manager

To: David Williams Planning
Control Manager

Our Ref:

Your Ref: P/2018/1060

Date: 27-12-2018

Town and Country Planning Act 1990

Town and Country Planning (General Development Procedure) Order 1996

Re: P/2018/1060, 16 CHESTER ROAD WREXHAM LL11 2SA

CHANGE OF USE OF SINGLE DETACHED GARAGE TO DOG GROOMING BUSINESS

ZP04 - AIR HANDLING / EXTRACTION PLANT BS4142 ASSESSMENT

If air handling plant is proposed:

The rating level of any noise generated by air handling plant associated with the development shall not exceed the pre-existing background level by more than 5dB(A) at any time. The noise levels shall be determined at nearby noise sensitive premises, and measurements and assessment shall be made in accordance with BS4142:2014 Methods for rating and assessing industrial and commercial sound.

Contaminated Land - No Comments

No Comments

.....
Head of Planning and Environment