

Wrexham County Council
6 Lord Street
WREXHAM
LL11 1LG

Date: 05/02/2019
Our Ref: PLA0039268
Your Ref: P/2018/0976

Dear Sir

Grid Ref: SJ2973443243 329734 343243

Site: Ruabon Business Park, Site Adj to A483, Ruabon, Wrexham

Development: Application for approval of details reserved by condition imposed under planning P/2018/0053 Condition 12 - Submission of scheme for relevant phase of development, for the comprehensive and integrated drainage of the site

We refer to your planning consultation relating to the above site, and we can provide the following comments in respect to the proposed development.

SEWERAGE

Having reviewed the revised details submitted in support of the above application (drawing numbers 8951/D/102 Rev T1 and 8951/D/101 Rev T1), we note that it is proposed for foul flows to be communicated with manhole SJ29438401 on the 525mm public combined sewer and surface water is to be disposed of via a soakaway system. These drainage arrangements are considered to be acceptable in principle.

We would advise that no structure, building or soakaway should be located within 6 metres either side of the centreline of the public sewer.

ADVISORY NOTE

Please note that the applicant has **not** obtained approval under Section 104 of the Water Industry Act 1991 for the formal adoption of drainage. The drainage proposal will be subject to Welsh Minister design and Sewers for Adoption (7th Edition) standards. It is a mandatory requirement for the applicant to obtain Section 104 approval for the laying of adoptable drainage. Should the proposal alter as a result of the Section 104 process, the applicant will be responsible for notifying the Local Planning Authority.

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at developer.services@dwrcymru.com

Please quote our reference number in all communications and correspondence.

Yours faithfully,



Alaw Jones
Development Control Officer
Developer Services