

15/01/2019

Er sylw / For the attention of Kevin Hughes

Dear Mr Hughes,

**BWRIAD / PROPOSAL: ERECTION OF STORAGE UNITS AND BUILDING FOR
LIGHT ENGINEERING (BLOCK 2)**

**LLEOLIAD / LOCATION: PLOT B, SITE 4000, CLYWEDOG ROAD, SOUTH
WREXHAM INDUSTRIAL ESTATE, WREXHAM
P/2018/1059**

Thank you for consulting Natural Resources Wales about the above, which was received on 18/12/2018.

NRW has no objection to the above scheme.

Flood Risk

As there may be culverting of an ordinary watercourse, we would advise you to consult the LPA's own drainage department in their capacity as lead local flood authority who may be able to advise on any local problems in relation to surface water disposal and any associated flood risk.

Protected Species

We note that there is no information about protected species with the application and, therefore, are assuming that your Authority has screened the application and concluded that there is not a reasonable likelihood of protected species being present.

Please do not hesitate to contact us if you require further information or clarification of any of the above.

Our comments above only relate specifically to matters that are listed in our 'Consultation Topics' document (September 2018) which is published on our

website: (<https://cdn.naturalresources.wales/media/686847/dpas-consultation-topics-august-2018-eng.pdf?mode=pad&rnd=131819256840000000>). We have not considered potential effects on other matters and do not rule out the potential for the proposed development to affect other interests, including environmental interests of local importance.

Advice for the Developer

Works near Water Course/ Construction Site:

Due to the proximity of the site to watercourses, all works at the site must be carried out in accordance with GPP5 and PPG6: 'Works in, near or over watercourses' and 'Working at construction and demolition sites' which are available on the following website: <http://www.netregs.org.uk/environmental-topics/pollution-prevention-guidelines-ppgs-and-replacement-series/guidance-for-pollution-prevention-gpps-full-list/>

During the construction phase you should take any precaution to prevent contamination of surface water drains and local watercourses. Oils and chemicals should be stored in bunded areas and spill kits should be readily available in case of accidental spillages.

For further guidance please refer to GPP 5 and PPG 6 as per the above link.

Environmental Management/ Pollution Prevention:

The activity of importing waste into the site for use as, for example hardcore, must be registered with Natural Resources Wales as an exempt/permittable activity under the Environmental Permitting Regulations 2016. The developer should contact Natural Resources Wales to discuss the necessity for an exemption/permit for any material imported to and exported from the site.

Waste:

Waste produced during the construction phase of your development must be dealt with appropriately and be in line with all relevant waste legislation including Duty of Care Regulations and Hazardous Waste Regulations. As part of your waste duty of care you must classify the waste produced:

- before it is collected, disposed of or recovered
- to identify the controls that apply to the movement of the waste
- to complete waste documents and records
- to identify suitably authorised waste management options
- to prevent harm to people and the environment.

Any waste removed from site will be subject to waste management controls. The links below provide information on how to classify waste and register as a waste carrier or hazardous waste producer:

<https://naturalresources.wales/permits-and-permissions/waste/?lang=en>

<https://naturalresources.wales/permits-and-permissions/waste/waste-permits/?lang=en>

Further guidance can be found on the GOV website here:

<https://www.gov.uk/managing-your-waste-an-overview/duty-of-care>

Bedrock:

The proposed development is in an area of bedrock aquifer. This designation is consistent with the Water Framework Directive and reflects the importance of aquifers in terms of groundwater as a resource (drinking water supply) and also their role in supporting surface water flows and wetland ecosystems.

In the event that surface water from the development discharges to ground, we refer the developer to the Groundwater Protection: Principles and Practice (Environment Agency, 2013) Position Statements. In particular, the developer should be aware that the advice under Position Statements G11 (Discharge from areas subject to contamination) and G13 (Sustainable drainage systems) applies to this development:

https://www.gov.uk/government/uploads/system/uploads/attachment_data/file/658135/LIT_7660.pdf

The applicant should be advised that, in addition to planning permission, it is their responsibility to ensure that they secure all other permits/consents relevant to their development.

Yours faithfully,

Joy Evans

Ms Joy Evans
Cynghorydd Cynllunio Datblygu /
Development Planning Advisor