

Susan Davies

From: Matthew Phillips
Sent: 06 February 2018 12:46
To: planning_admin
Subject: FW: P/2018/0019

Flood Officer comments

From: Neil Taunt
Sent: 06 February 2018 11:58
To: Matthew Phillips
Subject: P/2018/0019

Hi Matthew,

I have reviewed the submitted information with regards to the discharge of the surface water element of condition 3. The submitted infiltration tests would indicate soakaway is a feasible means to dispose of surface water, but no sizing or supporting calculations would appear to have been submitted in support. Regardless of this, I would recommend that individual soakaway locations are tested during construction and sized according to local conditions.

If you have any questions please let me know.

Regards

Neil

Neil Taunt MCIWEM C.WEM CEnv CSci

Uwch Swyddog Rheoli Llifogydd / Senior Flood Management Officer



 01978 729734 / 07808 787632

 Amgylchedd a Chynllunio, Cyngor Bwrdeistref Sirol Wreccsam, De Ffordd yr Abaty, Ystad Ddiwydiannol Wreccsam, Wreccsam LL13 9PW

 Environment & Planning, Wrexham County Borough Council, Abbey Road South, Wrexham Industrial Estate, Wrexham LL13 9PW

 wreccsam.gov.uk | wrexham.gov.uk

 twitter.com/cbswreccsam | twitter.com/wrexhamcbc

 facebook.com/cyngorwreccsam | facebook.com/wrexhamcouncil