

# MEMORANDUM



**From:** Service Manager Environment

**To:** Head of Community Well Being  
and Development

**Our Ref:** P/2017/0445

**Your Ref:** P/2017/0445

**Date:** 13 November 2017

---

**Town and Country Planning Act 1990**

**Section 78 Appeal at LAND AT BERSE ROAD, NEW BROUGHTON, WREXHAM,**

I am satisfied with the original responses made to this application and wish to inform you that I have no further comments to add.

Copies of the responses are attached for your information.

[Redacted Signature]

*M* Service Manager Environment

# MEMORANDUM



**From:** Service Manager Environment  
**To:** Head of Community Well-being and Development  
**Our Ref:** P/2017/0445  
**Your Ref:** P/2017/0445  
**Date:** 27 June 2017

**TOWN AND COUNTRY PLANNING ACT 1990**  
**TOWN AND COUNTRY (GENERAL DEVELOPMENT PROCEDURE) ORDER 1995**

**Location:** O. S Grid Ref: 3184 5102 Land at Berse Road, New Broughton  
**Development:** Conversion of redundant two storey steel framed barn to dwelling

I refer to your consultation dated 13 May 2017 in respect of the above.

It is proposed to access the site via the existing driveway which currently serves a barn and stables. Adequate visibility is provided at the existing access.

There is adequate space within the curtilage of the site to provide off road parking for the development.

I recommend that any permission include the following condition:

**CONDITION**

**ZJ22  
035R**

**PARKING AND MANOEUVRING TO BE KEPT CLEAR**

The vehicular parking and turning areas as shown on approved drawing(s) No(s). @@@@ shall be fully laid out, surfaced and drained prior to first use of the development. These areas shall thereafter be permanently retained and kept free of any obstruction, and made available solely for the parking and turning of vehicles at all times.

**ZJO9  
033R**

**NO GATES**

There shall be no gates or other means of enclosure across the vehicular access point within 5 metres of the highway boundary.

**ZJ15  
038R**

**VISIBILITY SPLAYS IN BOTH DIRECTIONS (NEAR SIDE)**

Prior to first use of the development hereby approved the vehicular access shall provide visibility splays of 2.4 metres x 120 metres in both directions measured to the nearside edge of the adjoining highway. Within these splays there shall be no obstruction in excess of 1 metre in height above the level of the nearside edge of the adjoining highway. The splays shall thereafter be permanently retained clear of any such obstruction to visibility.

  
Service Manager Environment