

CG0408201 permit variation 2007

creu lle gwell
creating a better place

CONSENT NO.	CG0408201
-------------	-----------



Asiantaeth yr
Amgylchedd Cymru
Environment
Agency Wales

ENVIRONMENT AGENCY

**WATER RESOURCES ACT 1991
(As amended by the Environment Act 1995)**

NOTICE OF MODIFICATION OF CONSENT TO DISCHARGE

TO: Managing Director
Knolton Farmhouse Cheese Limited
Overton-on-Dee
Wrexham
LL13 0LG

WHEREAS the Agency in pursuance of its powers under the Water Resources Act 1991 (as amended by the Environment Act 1995) **MODIFIED ITS CONSENT** to the making of a discharge of **TRADE EFFLUENT** on the 5th day of November 2004

FROM Knolton Farmhouse Cheese Limited

the Agency in pursuance of its powers under the Water Resources Act 1991 (as amended by the Environment Act 1995) hereby **GIVES NOTICE** that **CONSENT** CG0408201 is hereby modified as follows:

Trade Effluent

FROM: Knolton Farmhouse Cheese Limited

AT: Overton-on-Dee, Wrexham

TO: the River Dee

The conditions of Consent number CG0408201 are modified as detailed in this notice.

Subject to the provisions of Paragraphs 7 and 8 of Schedule 10 of the Water Resources Act 1991, no notice shall be served by the Agency which alters the effect of modifications made by this notice, without the agreement in writing of the Consent Holder, during a period of 4 years from the date this notice is served.

Dated this 1st day of February 2007

Signed

**IWAN WILLIAMS
Regulatory Water Quality Team Leader**

Asiantaeth yr Amgylchedd Ffordd Caer, Bwcle, Sir Fflint CH7 3AJ Ffon 08708 506506 Ffacs 01244 550144
Environment Agency Chester Road, Buckley, Flintshire CH7 3AJ Tel 08708 506506 Fax 01244 550144



creu lle gwell
creating a better place



Asiantaeth yr
Amgylchedd Cymru
Environment
Agency Wales

CONSENT NO.	CG0408201
SCHEDULE NO.	CG0408201 01
DATED	1 st February 2007

Conditions to be modified:

The following condition shall now be modified:

13. The mean concentration of total phosphorus expressed as P in any series of samples of the Discharge taken at regular but randomised intervals in any period of twelve consecutive months shall not exceed 11 milligrammes per litre.

Other conditions of the consent

All other conditions of the consent remain in force. Consent CG0408201 is updated accordingly.

