

Cerys Jones

From: Philip Forster
Sent: 04 July 2017 08:48
To: planning_admin
Subject: FW: P/2017/0490 - Cae Mor Farm

Consultation response - flood

From: Philip Forster
Sent: 04 July 2017 08:47
To: Richard Corbett
Subject: FW: P/2017/0490 - Cae Mor Farm

Dear Richard,

In relation to the above mentioned application to discharge conditions for Cae Mor Farm, please can you provide the calculations as requested by our Flood Management Officer as per the email below.

Many thanks

Phil
Philip Forster
Swyddog Cynllunio/Planning Officer
Rheoli Datblygu /Development Control



01978 298786
Cyngor Bwrdeistref Sirol Wrecsam, Neuadd y Dref, Wrecsam LL11 1AY
Wrexham County Borough Council, Guildhall, Wrexham LL11 1AY
wrecsam.gov.uk | wrexham.gov.uk
twitter.com/cbswrecsam | twitter.com/wrexhamcbc
facebook.com/cyngorwrecsam | facebook.com/wrexhamcouncil

From: Neil Taunt
Sent: 04 July 2017 07:33
To: Philip Forster
Subject: P/2017/0490

Hi Phil,

Thanks you for the recent consultation on the above discharge of condition application.

Prior to being able to comment on the submission I would request that dimensions of the proposed soakaway, with supporting sizing calculations in accordance with BRE 365 are submitted.

Many thanks

Neil

Neil Taunt MCIWEM C.WEM CEnv CSci



01978 729734 / 07808 787632



Amgylchedd a Chynllunio, Cyngor Bwrdeistref Sirol WreCsam, De Ffordd yr Abaty, Ystad Ddiwydiannol WreCsam, WreCsam LL13 9PW



Environment & Planning, Wrexham County Borough Council, Abbey Road South, Wrexham Industrial Estate, Wrexham LL13 9PW



wreCsam.gov.uk | wrexham.gov.uk



twitter.com/cbswreCsam | twitter.com/wrexhamcbc



facebook.com/cyngorwreCsam | facebook.com/wrexhamcouncil