



MEMORANDUM

From:	Ian Jones Public Protection	To:	David Williams Planning
	Service Manager		Control Manager
Our Ref:		Your Ref:	P/2017/0588
Date:	24-07-2017		

Town and Country Planning Act 1990

Town and Country Planning (General Development Procedure) Order 1996

Re: P/2017/0588, KELLOGGS BRYN LANE WREXHAM INDUSTRIAL ESTATE WREXHAM

INTRODUCTION OF 3 NO. AIR HANDLING / AIR CLEANING UNITS ON TO THE EXISTING FLAT ROOF AREA OF THE BUILDING (EMISSION POINTS / FLUES EXTEND UPWARDS TO 16M ABOVE GROUND FLOOR LEVEL - 8M ABOVE RESPECTIVE ROOF LEVEL)

Contaminated Land

No Comments

Environmental Protection

ZP04 - AIR HANDLING / EXTRACTION PLANT BS4142 ASSESSMENT

The rating level of any noise generated by air handling plant associated with the development shall not exceed the pre-existing background level by more than 5dB(A) at any time. The noise levels shall be determined at nearby noise sensitive premises, and measurements and assessment shall be made in accordance with BS4142:2014 Methods for rating and assessing industrial and commercial sound.

.....

Head of Planning and Environment