

MEMORANDUM



From: Service Manager Environment **To:** Head of Environment and Planning
Our Ref: EP/DC/PP/2017/0079 **Your Ref:** SEH/P/2017/0079
Date: 12th May 2017

TOWN AND COUNTRY PLANNING ACT 1990
TOWN AND COUNTRY (GENERAL DEVELOPMENT PROCEDURE) ORDER 1995

Location: O. S Grid Ref: 415 394 The Lodge, Tudor Drive, Llanerch Panna, Penley, Wrexham.

Development: Erection of 5 no. dwellings and associated access works.

I refer to your consultation dated 12/05/2017 in respect of the above.

I have no objections to the proposed application and would recommend that any permission includes the following conditions :-

CONDITIONS

- ZJ41** **GENERAL LAYOUT**
026R Prior to first use of the development the site shall be laid out in strict accordance with layout plan(s) No. **16-22 A22100 Rev M.**
- ZJ19** **VISIBILITY SPLAYS (NEARSIDE AND CENTRELINE)**
038R Prior to first use of the development hereby approved the vehicular access shall provide visibility splays of 2.4 metres x 25 metres to the west measured to the nearside edge of the adjoining highway and 2.4 metres x 33 metres to the east measured to the centreline of the adjoining highway. Within these splays there shall be no obstruction in excess of 1 metre in height above the level of the adjoining carriageway. The splays shall thereafter be permanently retained clear of any such obstruction to visibility.
- ZJ11** **ACCESS WIDTH**
039R The vehicular access hereby approved shall be a minimum width of 4.8 metres.
- ZJ07** **ACCESS SURFACE (5 metres)**
043R Prior to first use of the vehicular access hereby approved, the access shall be surfaced with hard bound materials (e.g. bituminous macadam) for a minimum distance of 5 metres behind the adjoining highway.
- ZJ09** **NO GATES WITHIN 5 METRES**
033R There shall be no gates or other means of enclosure across the vehicular access point within 5 metres of the highway boundary.

- NONSTD** **NO PRIVATE SURFACE WATER RUN OFF**
026R No private surface water run off shall be permitted to flow from the development site onto the adjoining highway. An Aco drain or similar shall be provided across the approved accesses to intercept any such run off prior to first use of the development.
- ZJ13** **DROPPED KERB VEHICULAR CROSSING**
026R The vehicular access(es) hereby approved shall take the form of a dropped kerb vehicular crossing.
- NONSTD** **PRIVATE MANAGEMENT COMPANY**
026R The unadopted estate road shall be maintained in perpetuity by a private management company.

Supplementary Notes

The applicant's attention should be drawn to item nos. 1, 2, 3, 4 & 5 of the supplementary notes.

Note to Applicant

- **VERGE CROSSING LICENCE**
A licence should be obtained (as required by section 184 of the Highways Act 1980) from the Highway Authority in order to lower the kerblin and cross the highway verge at the new access positions. Further guidance can be obtained from the Highways Department of Wrexham County Borough Council on telephone 01978 729670.

Peter Cartwright

M Service Manager Environment