

Clare Whiting

From: Matthew Phillips
Sent: 03 April 2017 09:51
To: planning_admin
Subject: FW: P/2017/0165

Please add email as Public Protection response

From: Nick Minshall
Sent: 29 March 2017 17:03
To: Matthew Phillips
Subject: RE: P/2017/0165

Hello Matthew

The chemical scrubber details and the OMP look fine.

The recommendations detailed in Section 9 of the Environoise Impact Assessment suggest that compliance with the Planning permission noise condition should be achieved.

I would recommend that daily visual assessments and recording of the results of the assessments should be incorporated into the proposed DMS.

Regards Nick

From: Matthew Phillips
Sent: 20 March 2017 10:13
To: Nick Minshall; Paul Campini
Subject: P/2017/0165

Nick/Paul,

Please see attached – documents submitted to support planning application P/2017/0165. With the exception of the chemical scrubber details the submissions are identical to the ones with application P/2017/0204 for approval of details required by conditions attached to previous planning permissions.

Regards

Matthew Phillips
Planning Control Lead/Arweinydd Rheoli Cynllunio
Environment and Planning/Amgylchedd a Chynllunio
Wrexham County Borough Council/Cyngor Bwrdeistref Sirol Wrecsam
Telephone/Ffôn: 01978 298780