



MEMORANDUM

From: Toni Slater Public Protection
Service Manager

To: David Williams Planning
Control Manager

Our Ref:

Your Ref: P/2017/0304

Date: 28-04-2017

Town and Country Planning Act 1990

Town and Country Planning (General Development Procedure) Order 1996

Re: P/2017/0304, BARN 1 HOLT LODGE FARM HUGMORE LANE LLAN Y PWLL WREXHAM

INSTALLATION OF OIL TANK TOGETHER WITH SCREEN WALL, ERECTION OF SHED AND 1.2M HIGH POST AND RAIL FENCE WITH GATED ACCESS TO REAR GARDEN ENCLOSURE

Environmental Protection

ZP17 - (BUND) STORAGE OF OILS, FUELS AND CHEMICALS

Any facilities above ground provided for the storage of oils, fuels or chemicals shall be sited on an impervious base and surrounded by impervious walls. The volume of the bunded compound shall be at least equivalent to the capacity of the tank plus 10%. All filling points, vents, gauges and sight glasses must be located within the bund. The drainage system of the bund shall be sealed with no discharge to any watercourse, land or underground strata. Associated pipe work must be located above ground and protected from accidental damage. All filling points and tank overflow pipe outlets must be discharged into the bund.

Contaminated Land

No Comments

.....

Head of Planning and Environment