

From: Raynor-Evans, Katrin [<mailto:Katrin.Raynor-Evans@cyfoethnaturiolcymru.gov.uk>]
Sent: 06 March 2017 13:43
To: Stuart Latham <stuart.latham@kfcheese.co.uk>
Subject: RE: Discharge permit

Thanks Stuart. I've attached copies of all of the permits.

With regard to the surface water discharge, you told me that surface water and treated effluent meet within the same discharge pipe to the watercourse. This is fine. We would not want any surface water entering the treatment plant as this creates a higher volume of effluent and can also affect the working of the treatment plant.

If you need anything else, please get in touch.

Many thanks

Katrin

Enw/Name : Katrin Raynor-Evans BSc (Hons) MSc FRAS FRGS

Teitl/Title: Swyddog Trwyddedu/Permitting Officer

Adnoddau Dŵr: Water Quality Permitting

Cyfarwyddiaeth Tystiolaeth, Polisi a Thrwyddedu/ Evidence, Policy and Permitting Directorate

Cyfoeth Naturiol Cymru /Natural Resources Wales

Ffôn/ Tel: 03000 654 427

E-bost/Email: Katrin.raynor-evans@cyfoethnaturiolcymru.gov.uk

Yn falch o arwain y ffordd at ddyfodol gwell i Gymru trwy reoli'r amgylchedd ac adnoddau naturiol yn gynaliadwy.

Proud to be leading the way to a better future for Wales by managing the environment and natural resources sustainably.



Croesewir gohebiaeth yn y Gymraeg a'r Saesneg Correspondence welcomed in both Welsh and English.