

Cerys Jones

From: Matthew Phillips
Sent: 23 December 2016 08:53
To: planning_admin
Subject: FW: Ardagh Gorup

Public protection comments P/2016/1151

From: Paul Campini
Sent: 21 December 2016 09:25
To: Matthew Phillips
Subject: Ardagh Gorup

Hi Matthew

With reference to Ardagh's planning application (P/2016/1151), I've just had a look at it and seen that there is no noise assessment for the development. I have recommended a condition to this effect but thought I should let you know as well. It's our usual one that I've recommended:

The rating level of any noise generated by reason of this development shall not exceed the pre-existing background level by more than 5dB(A) at any time. The noise levels shall be determined at nearby noise sensitive premises, and measurements and assessment shall be made in accordance with BS4142:2014 Methods for rating and assessing industrial and commercial sound.

Regards

Paul Campini
Technical Officer / *Swyddog Technegol*
Environmental Protection / *Diogelu'r Amgylchedd*



☎ 01978 297431
✉ Wrexham County Borough Council, Guildhall, Wrexham LL11 1AY
✉ Cyngor Bwrdeistref Sirol Wrecsam, Neuadd y Dref, Wrecsam LL11 1AY
🌐 wrexham.gov.uk | wrecsam.gov.uk
🐦 twitter.com/wrexhamcbc | twitter.com/cbswrecsam
📘 facebook.com/wrexhamcouncil | facebook.com/cyngorwrecsam



The Housing (Wales) Act 2014

The new law requires all landlords to register and agents and self-managing landlords to obtain a licence.

<https://www.rentsmart.gov.wales> or call 03000 133344

Deddf Tai (Cymru) 2014

Mae deddf newydd yn gofyn i bob landlord gofrestru ac mae angen i asiantau a landlordiaid sy'n hunan reoli gael trwydded.

<https://www.rhentudoeth.llyw.cymru> neu ffoniwch 03000 133344

