

AnnS Jones

From: Matthew Phillips
Sent: 07 February 2017 14:38
To: planning_admin
Subject: FW: P/2016/0894 - School Lane, Wrexham

Flood officer comments to the above

From: Neil Taunt
Sent: 06 February 2017 14:15
To: Matthew Phillips
Subject: RE: P/2016/0894 - School Lane, Wrexham

Hi Matthew,

The submitted clarification does indicate that the soakaway design would be appropriate considering the infiltration rates determined. I would recommend that during construction additional testing is carried out to ensure ground conditions encountered at the remaining soak away locations are as expected. If not then the soakaway design should be modified according to the local ground conditions experiences.

Many thanks

Neil

From: Matthew Phillips
Sent: 27 January 2017 11:39
To: Neil Taunt
Subject: FW: P/2016/0894 - School Lane, Wrexham

Neil,

Please see below and attached.

From: Peter Moffatt [<mailto:peter@williamjonesandpartners.co.uk>]
Sent: 26 January 2017 13:20
To: Matthew Phillips
Cc: FSP Northern
Subject: FW: P/2016/0894 - School Lane, Wrexham

Dear Matthew,

Could you please forward this response from the site investigation firm regarding the soakaways to Neil Taunt – I don't appear to have his direct email address.

Hopefully this will clarify the outstanding query.

Regards

Peter J. Moffatt
Director

William Jones & Partners
Consulting Civil & Structural Engineers,
UNIT 11 CONNECT BUSINESS VILLAGE
24 DERBY ROAD, LIVERPOOL L5 9PR

Tel : (+44) 0151 298 1937

Fax :(+44) 0151 298 1961

Mobile 07718527253

Email: info@williamjonesandpartners.co.uk