

MEMORANDUM

From:	Service Manager Environment	To:	Head of Environment and Planning
Our Ref:	TH/DC/AC/P/2017/0171		
Date:	02 March 2017	Your Ref:	P/2017/0171

TOWN AND COUNTRY PLANNING ACT 1990

Location: O. S Grid Ref: 3148 The Pharmacy, Trinity Street, Rhostyllen
Development: Display of double sided externally illuminated projecting sign

I refer to your consultation dated 02 March 2017 in respect of the above.

In principle I have no objections to development proposals at this site and I would recommend any permission include the following condition:-

CONDITION

1. The proposed lighting scheme shall not be illuminated in such a manner that they present any disabling glare or dazzle to the traffic using the adjacent highway.

REASON

1. To prevent glare or dazzle in the interest of traffic safety.

Supplementary Notes

The applicant's attention should be drawn to item nos. 1, 3, 4 & 5 of the supplementary notes.

Peter Douthwaite

PD Service Manager Environment