

Cerys Jones

From: Matthew Phillips
Sent: 07 December 2015 16:53
To: planning_admin
Subject: FW: P/2015/0900

Public protection response

From: Nick Minshall
Sent: 07 December 2015 16:01
To: Matthew Phillips
Subject: P/2015/0900

Hello Matthew

Further to our telephone conversation earlier this afternoon I confirm that the EP Section does have concerns regarding external amenity due to road traffic noise. The Environoise survey suggests that noise levels in the garden area will vary between 53-55dB LAeq(16-hour) with noise mitigation provided by a 2.4m high close boarded fence. It should be noted that both the WHO and BS8223 recommend that noise levels for external amenity spaces should be less than 50dB LAeq(16-hour) to prevent moderate annoyance with 55dB LAeq(16-hour) regarded as an upper limit in order to prevent serious annoyance for occupants.

Nick Minshall

Pollution Control Officer / *Swyddog Rheoli Llygredd*
Environmental Protection / *Diogelu'r Amgylchedd*

✉ Housing, Public Protection and Environment Department, Ruthin Road, Wrexham LL13 7TU
✉ **Adran Tai, Gwarchod y Cyhoedd a'r Amgylchedd , Ffordd Rhuthun, Wrecsam LL13 7TU**
☎ Tel / Ffon : 01978 297430
☎ Fax / Ffacs : 01978 315701
✉ e-mail / ebost : nick.minshall@wrexham.gov.uk

Find us on:

<http://www.wrexham.gov.uk/>
http://www.wrexham.gov.uk/english/env_services/environmental_protection/index.htm
http://www.wrexham.gov.uk/welsh/env_services/environmental_protection/index.htm
twitter.com/wrexhamcbc
facebook.com/wrexhamcouncil



We aim to provide our service fairly and we monitor our services to check we are meeting this standard. To help us do this I would be grateful if you would visit the following link <http://www.surveymonkey.com/s/ppequalitymonitoring> and complete the equality questionnaire, which will only take about 2 minutes of your time. Note that this questionnaire is anonymous.

If you wish to receive a hard copy of the questionnaire or require it in a different language then please telephone 01978 298989 or email your request and postal address to public_protection_service@wrexham.gov.uk.

Ein nod yw darparu ein gwasanaeth i chi mewn ffordd deg ac rydym yn monitro ein gwasanaethau i wneud yn siŵr ein bod yn cyflawni'r safon hon. I'n helpu i wneud hyn, byddwn yn ddiolchgar pe byddech yn mynd i'r cyswllt canlynol <http://www.surveymonkey.com/s/ppequalitymonitoringwelsh> ac yn cwblhau'r holiadur cydraddoldeb, a fydd ond yn cymryd tua 2 funud o'ch amser.

Os hoffech dderbyn copi papur o'r holiadur neu os ydych am ei dderbyn mewn iaith wahanol, yna ffoniwch 01978 298989 neu anfonwch eich cais a'ch cyfeiriad post drwy e-bost i public_protection_service@wrexham.gov.uk.

