

Cerys Jones

From: Philip Forster
Sent: 03 November 2015 08:19
To: planning_admin
Subject: FW: P/2015/0702 - Austin Eames site

Public Protection response

From: Nick Minshall
Sent: 02 November 2015 09:12
To: Philip Forster
Subject: RE: P/2015/0702 - Austin Eames site

Hello Phil

The noise report doesn't contain any calculations to support the external noise reductions that can realistically be achieved by the proposed 2.5m high barrier(s).

Also the estimated external noise level of 54dBA is based upon recorded noise levels considered not to be representative.

Regards Nick

From: Philip Forster
Sent: 28 October 2015 17:21
To: Nick Minshall
Subject: P/2015/0702 - Austin Eames site

Hi Nick,

I'm writing up this application for refusal on the grounds of noise.

I am satisfied that there is reasonable evidence to justify this reason. I would just like to clear up possible noise mitigation in my report. What would be the reasons behind an acoustic fencing along the boundary being unacceptable? I want to cover this in the report if the applicant comes back to us with that question.

Thanks

Phil

Philip Forster

Planning Officer/Swyddog Cynllunio

Development Control/Rheoli Datblygu

Wrexham County Borough Council/Cyngor Bwrdeistref Sirol Wrecsam

☎ 01978 298786

✉ Wrexham County Borough Council, 16 Lord Street, Wrexham LL11 1LG

✉ Cyngor Bwrdeistref Sirol Wrecsam, 16 Stryt yr Arglwydd, Wrecsam LL11 1LG

💻 www.wrexham.gov.uk

www.twitter.com/wrexhamcbc

www.facebook.com/wrexhamcouncil

