Joanna Barnett

From: Matthew Phillips
Sent: 06 February 2013 15:19
To: planning_admin
Subject: FW: Gredington Arms

Discharge of condition submission - materials

P/2011/0745 and P/2012/0804

From: Dafydd Edwards [mailto:dafydd@blueprintarchitectural.com]
Sent: 06 February 2013 15:15
To: Matthew Phillips
Subject: Re: Gredington Arms

Matthew,

Render mix is to be as follows:

weber.pral M should be mixed with 5 - 5½ litres of clean water using either a suitable render spray machine, drill and whisk or tumble mixer.

To ensure colour consistency, the materials required for complete and adjoining panels should be of the same batch number or be thoroughly mixed together before use.y.

For best results, use as little water as possible and mix to give a workable consistency.

All information obtained from the following link:

http://www.netweber.co.uk/renders-decorative-finishes/weber-products/products/monocouche-renders/weberpral-m.html

Regards

Dafydd Edwards ACIOB
Senior Architectural Technician
For Blueprint Architectural Services

Tel: 01978 356500
Dafydd@blueprintarchitectural.com

From: Matthew Phillips
Sent: Wednesday, February 06, 2013 2:45 PM
To: Dafydd Edwards
Subject: Gredington Arms

Dafydd,

Whilst the samples have been submitted for permission P/2011/0804, there are similar conditions on the more recent permission P/2012/0804 for the removal and replacement of the existing render.

Condition 03 of P/2012/0804 requres a specification for the render mix in addition to the texture and finish shall. Are you able to provide this?

Regards

Matthew

Take a look - you can pay, report, request, have your say and find information online at www.wrexham.gov.uk. Save paper - think before you print! This e-mail message and any attachments are intended solely for the individual or organisation to whom it is addressed. For full conditions in relation to content and use of this e-mail message and any attachments, please refer to http://www.wrexham.gov.uk/top_navigation/disclaimers.htm. Mae'r neges e-bost hon ac unrhyw atodiadau wedi eu bwriadu ar gyfer yr unigolyn neu?r sefydliad y?i cyfeirir atynt yn unig. Am yr amodau llawn ynglyn a chynnwys a defnyddio?r neges e-bost hon ac unrhyw atodiadau, cyfeiriwch at http://www.wrecsam.gov.uk/top_navigation/disclaimersw.htm.