

MEMORANDUM



From: Network and Infrastructure Manager

To: Chief Planning Officer

Our Ref: P/2012/0722

Your Ref: P/2012/0722

Date: 30 October 2012

TOWN AND COUNTRY PLANNING ACT 1990.

TOWN AND COUNTRY (GENERAL DEVELOPMENT PROCEDURE) ORDER 1995.

Location: O. S Grid Ref: 3300 3970 McDonalds Restaurant, Chirk

Development: Erection of 9 lighting columns in car park

I refer to your consultation dated 17 October 2012 in respect of the above.

I recommend any permission include the following condition:

CONDITION

NONSTDR NO DISABLING GLARE

026R

The floodlights shall be illuminated in such a manner that they do not present any disabling glare or dazzle to the traffic using the adjacent highway

Peter Downwards

P.P Network and Infrastructure Manager