

MEMORANDUM

From:	Network and Infrastructure Manager	To:	Head of Community Well-being and Development
Our Ref:	ENV/DC/PP/P/2012/0422	Your Ref:	ENV/P/2012/0422
Date:	25 th June 2011		

TOWN AND COUNTRY PLANNING ACT 1990

TOWN AND COUNTRY (GENERAL DEVELOPMENT PROCEDURE) ORDER 1995

Location: O. S Grid Ref: 365 571 Side garden area adjoining Alyndene, Chester Road, Rossett, Wrexham.

Development: Erection of one dwelling, demolition of existing garage, erection of new garage block and alterations to vehicular access.

I refer to your consultation dated 19/06/2012 including layout plan (Drg.No. ISA 160 P 200) in respect of the above.

The development site is located on the B5445 Chester Road which is a busy classified road subject to a 30mph speed limit.

Any proposed / existing access would normally be required to provide visibility splays of 2.4 x 56m in both directions measured to the nearside edge of the adjoining highway in which there shall be no obstruction in excess of 1.0m in height in accordance with Manual for Streets.

Visibility from the existing access appears adequate in the easterly direction providing a splay in excess of 2.4 x 56m measured to the nearside edge of the adjoining highway. However, visibility in the south westerly direction is inadequate providing a splay of approximately 2.4 x 3m measured to the nearside edge of the adjoining highway. Visibility is impeded in this direction by the existing railings located on the footway along this section of Chester Road.

In order to provide the required visibility splay in this direction from the proposed shared access would require the removal of the first 3 no. sections including 3 no. posts of the existing railings located on the footway along this section. In order to carry out these modifications, the applicant will need to apply for formal consent pursuant to Section 184 of the Highways Act 1980 (see note).

The existing access will need to be widened to a minimum of 4.5m to form a suitable shared access. Any modifications to the footway to facilitate the modified access can be included as part of the s.184 consent.

I would recommend that the proposed shared access provides adequate pedestrian visibility providing splays of 2.4 x 3.3m in both directions measured from the back of the footway in which there shall be no obstruction in excess of 0.6m in height.

I would recommend that any proposed access is surfaced with hard bound materials for at least 5m behind the highway boundary. No gates shall be erected within 5m of the highway boundary.

Parking and turning facilities indicated on the submitted layout plan appear adequate for both the existing and proposed dwellings.

I would therefore recommend that any permission include the following conditions:-

CONDITIONS

- ZJ15**
038R **VISIBILITY SPLAYS IN BOTH DIRECTIONS (NEAR SIDE)**
Prior to first use of the development hereby approved the vehicular access shall provide visibility splays of 2.4 metres x 56 metres in both directions measured to the nearside edge of the adjoining highway. Within these splays there shall be no obstruction in excess of 1 metre in height above the level of the nearside edge of the adjoining carriageway. The splays shall thereafter be permanently retained clear of any such obstruction to visibility.
- ZJ20**
038R **PEDESTRIAN VISIBILITY SPLAY (FOOTWAY SAFETY)**
Prior to first use of the development hereby approved a pedestrian visibility splay shall be established measured from the centreline of the vehicular access 2.4 metres back from the back edge of the footway to points 3.3 metres either side measured along the back edge of the footway. Within these splays there shall be no obstruction in excess of 0.6 metres in height above the level of the adjoining highway. The splays shall thereafter be permanently retained clear of any such obstruction to visibility.
- ZJ07**
043R **ACCESS SURFACE (5 metres)**
Prior to first use of the vehicular access hereby approved, the access shall be surfaced with hard bound materials (e.g. bituminous macadam) for a minimum distance of 5 metres behind the adjoining highway.
- ZJ11**
039R **ACCESS WIDTH**
The vehicular access hereby approved shall be a minimum width of 4.5 metres.
- ZJ09**
033R **NO GATES**
There shall be no gates or other means of enclosure across the vehicular access point within 5 metres of the highway boundary.
- ZJ22**
035R **PARKING AND MANOEUVRING TO BE KEPT CLEAR**
The vehicular parking and turning areas as shown on approved drawing no. ISA 160 P 200 shall be fully laid out, surfaced and drained prior to first use of the development. These areas shall thereafter be permanently retained and kept free of any obstruction, and made available solely for the parking and turning of vehicles at all times.

Supplementary Notes

The applicant's attention should be drawn to item nos. 1, 3, 4 & 5 of the supplementary notes.

Note:

The applicant will need to widen the existing dropped kerb crossing outside the property including strengthening of the footway at the point of access including modifications to the existing railings sited in the footway and will need to apply for formal consent pursuant to Section 184 of the Highways Act 1980.

Please contact our Network Assistant – Jo Giles on Tel: 01978 729670 for further details.

A handwritten signature in blue ink, appearing to read 'D. Hill', is positioned above the title. The signature is fluid and cursive.

Network and Infrastructure Manager

