

MEMORANDUM



From: Network and Infrastructure Manager **To:** Chief Planning Officer

Our Ref: PD/P/2012/0129

Your Ref: SJG/P/2012/0129

Date: 14 March 2012

TOWN AND COUNTRY PLANNING ACT 1990.

TOWN AND COUNTRY (GENERAL DEVELOPMENT PROCEDURE) ORDER 1995.

Location: O. S Grid Ref: 3190 5460 Alyn Waters Country Park, Mold Road, Gwersyllt

Development: Installation of 100m of 1.8m high galvanised palisade fencing

I refer to your consultation dated 22 February 2012 in respect of the above.

The development site is located on a classified highway which is of restricted width. It is therefore important that carriageway and verge widths are not further restricted. The fence must therefore be erected no closer to the carriageway edge than the existing post and wire fence.

I recommend that any permission include the following condition:

CONDITION

NONSTDC LOCATION OF FENCE

026R The fence hereby approved shall be erected no closer to the carriageway edge than the existing post and wire fence.

Peter Oosthuizen

P.P.

Network and Infrastructure Manager