

Pamela Joseph

From: Sharon Holman
Sent: 25 April 2012 11:37
To: planning_admin
Subject: FW: P/2010/0820 Ventura Developments
Attachments: Sycamores External Lighting Plan 20.04.2012.pdf

please import attached plan and email below - discharge of condition - landscape submission

From: Sharon Holman
Sent: 25 April 2012 11:36
To: 'ak@venturadevelopments.co.uk'
Cc: 'Neil Jones'
Subject: FW: P/2010/0820 Ventura Developments

Hello Andrew,

Thank you for the plan and fitting details. I can confirm that the proposed lighting scheme is acceptable and that condition no. 10 of P/2010/0820 has now been fully discharged.

I will update the planning file accordingly.

Kind regards
Sharon

From: ak@venturadevelopments.co.uk [<mailto:ak@venturadevelopments.co.uk>]
Sent: 24 April 2012 16:56
To: Sharon Holman
Cc: Neil Jones - Munro's
Subject: P/2010/0820 Ventura Developments

Dear Sharon

Re: P/2010/0820 Condition 10 External Lighting

Please see the attached site layout plan illustrating the positions of all external lighting (indicated with a red symbol).

The fittings are:

- half lanterns fixed to front and rear elevations
- full lanterns on brick pillars at plots 4/5 drive ends
- 1m high bollards to plots 1/2/3 drive ends

All fittings use 18w low energy lamps and are controlled with dusk to dawn photocell sensors and on/off override switches within the properties.

All fittings comply with The Code for Sustainable Homes and Secured by Design requirements as specified for this development and are now installed should an inspection be required.

I trust this information is satisfactory for your requirements and will enable you to extinguish Condition 10.

Regards

Andrew Kennerley

Ventura Developments Ltd