Dŵr Cymru
Welsh Water

Developer Services
PO Box 3146
Cardiff
CF30 0EH

Tel: +44 (0)800 917 2652
Fax: +44 (0)2920 740472
E.mail: developer.services@dwrcymru.com

Gwasanaethau Datblygu
Blwch Post 3146
Caerdydd
CF30 0EH

Ffôn: +44 (0)800 917 2652
Ffacs: +44 (0)2920 740472
E.bost: developer.services@dwrcymru.com

Wrexham County Council
16 Lord Street
WREXHAM
LL11 1LG

Date: 20/10/2025
Our Ref: c
Your Ref: P/2025/0764

Dear Sir/Madam

Grid Ref: SJ338497 333896 349736
Site: 49 Kingsmills Road, Wrexham
Development: Change of use of building from class a1 (post office) to class c3 (dwelling)

We refer to your planning consultation relating to the above site, and we can provide the following comments in respect to the proposed development.

We would request that if you are minded to grant Planning Consent for the above development that the **Conditions and Advisory Notes** provided below are included within the consent to ensure no detriment to existing residents or the environment and to Dwr Cymru Welsh Water's assets.

FOUL WATER DRAINAGE – SEWERAGE NETWORK

We can confirm capacity exists within the public sewerage network in order to receive the domestic foul only flows from the proposed development site.

The proposed development site is located in the catchment of a public sewerage system which drains to Five Fords Wastewater Treatment Works (WwTW) and ultimately discharges to a river Special Area of Conservation (SAC). We would advise that this WwTW has a phosphorus consent limit and is currently compliant with the 95% quartile for its flow passed forward (FPF) performance, at the time of this consultation. Accordingly, we would advise there is currently suitable hydraulic capacity in the public sewerage system and downstream WwTW to accommodate foul water flows from the development subject of this application.

Surface Water Drainage

We note that the proposal does not identify how it intends to dispose of surface water.

glas
Glas Cymru Cyfyngedig

Welsh Water is owned by Glas Cymru – a 'not-for-profit' company.
Mae Dŵr Cymru yn eiddo i Glas Cymru – cwmni 'nid-er-elw'.

We welcome correspondence in Welsh and English

Dŵr Cymru Cyf, a limited company registered in Wales no 2366777. Registered office: Pentwyn Road, Nelson, Treharris, Mid Glamorgan CF46 6LY

Rydym yn croesawu gohebiaeth yn y Gymraeg neu yn Saesneg

Dŵr Cymru Cyf, cwmni cyfyngedig wedi'i gofrestru yng Nghymru rhif 2366777. Swyddfa gofrestredig: Heol Pentwyn Nelson, Treharris, Morgannwg Ganol CF46 6LY.

Please be advised that under no circumstances would we allow surface water or highway run-off from the proposed development to communicate directly or indirectly with the public combined sewer. In addition, please note, no amount of land drainage run-off is permitted to discharge directly or indirectly into the public sewerage system.

As of 7th January 2019, this proposed development is subject to Schedule 3 of the Flood and Water Management Act 2010. The development therefore requires approval of Sustainable Drainage Systems (SuDS) features, in accordance with the 'Statutory standards for sustainable drainage systems – designing, constructing, operating and maintaining surface water drainage systems'. As highlighted in these standards, the developer is required to explore and fully exhaust all surface water drainage options in accordance with a hierarchy preferring infiltration (PL2) and, where infiltration is not possible, disposal to a surface water body (PL3), in liaison with the Lead Local Flood Authority and/or Natural Resources Wales, or surface water sewer or highway drain (PL4) in liaison with the riparian owner and/or Local Highways Authority.

Please note, DCWW is a statutory consultee to the SAB application process and will provide comments to any SuDS proposals by response to SAB consultation. Please refer to further detailed advice relating to surface water management included in our attached Advice & Guidance note and our Developer Services website at https://developers.dwrcymru.com/en/help-advice/regulation-to-be-aware-of/sustainable-drainage-systems.

We therefore would request the following Condition and Advisory Notes to be imposed to any future consent.

Conditions

No surface water from any increase in the roof area of the building /or impermeable surfaces within its curtilage shall be allowed to drain directly or indirectly to the public sewerage system.

Reason: To prevent hydraulic overloading of the public sewerage system, to protect the health and safety of existing residents and ensure no pollution of or detriment to the environment.

Advisory Notes

In accordance with Planning Policy Wales (Edition 12) and Technical Advice Note 12 (Design), the applicant is advised to take a sustainable approach in considering water supply in new development proposals, including utilising approaches that improve water efficiency and reduce water consumption. We would recommend that the applicant liaises with the relevant Local Authority Building Control department to discuss their water efficiency requirements.

The proposed development may be subject to Schedule 3 of the Flood and Water Management Act 2010. The development therefore may require approval of Sustainable Drainage Systems (SuDS) features, in accordance with national standards, and is strongly recommended that the developer engage in pre-application consultation with the Local Authority, as the relevant SuDS Approval Body (SAB), in relation to their proposals for SuDS features. Please note, Dwr Cymru Welsh Water is a statutory consultee to the SAB application process and will provide comments to any SuDS proposals by response to SAB consultation.

The applicant is advised that some public sewers and lateral drains may not be recorded on our maps; some sewers were originally privately owned and were transferred into public ownership by nature of the Water Industry (Schemes for Adoption of Private Sewers) Regulations 2011. The presence of such assets may affect the proposal. In order to assist us in dealing with the proposal the applicant may contact Dwr Cymru Welsh Water. Under the Water Industry Act 1991 Dwr Cymru Welsh Water has rights of access to its apparatus at all times.

The applicant may also need to apply to Dwr Cymru / Welsh Water for any connection to the public sewer under S106 of the Water industry Act 1991. If the connection to the public sewer network is either via a lateral drain (i.e. a drain which extends beyond the connecting property boundary) or via a new sewer (i.e. serves more than one property), it is now a mandatory requirement to first enter into a Section 104 Adoption Agreement (Water Industry Act 1991). The design of the sewers and lateral drains must also conform to the Welsh Ministers Standards for Gravity Foul Sewers and Lateral Drains, and conform with the publication "Sewers for Adoption"- 7th Edition. Further information can be obtained via the Developer Services pages of www.dwrcymru.com.

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at **developer.services@dwrcymru.com**

Please quote our reference number in all communications and correspondence.

Yours faithfully,

Olivia Davis
Development Planning Officer
Developer Services

glas
Glas Cymru Cyfyngedig

Welsh Water is owned by Glas Cymru – a 'not-for-profit' company.
Mae Dŵr Cymru yn eiddo i Glas Cymru – cwmni 'nid-er-elw'.

We welcome correspondence in Welsh and English

Dŵr Cymru Cyf, a limited company registered in Wales no 2366777. Registered office: Pentwyn Road, Nelson, Treharris, Mid Glamorgan CF46 6LY

Rydym yn croesawu gohebiaeth yn y Gymraeg neu yn Saesneg

Dŵr Cymru Cyf, cwmni cyfyngedig wedi'i gofrestru yng Nghymru rhif 2366777. Swyddfa gofrestredig: Heol Pentwyn Nelson, Treharris, Morgannwg Ganol CF46 6LY.