wrexham
COUNTY BOROUGH COUNCIL
CYNGOR BWRDEISTREF SIROL
wrecsam

MEMORANDUM

From: **Ian Jones**
Head of Service Public Protection

To: **Matthew Phillips**
Head of Service Planning Development

Our Ref:

Your Ref: P/2025/0773

Date: 04-11-2025

Town and Country Planning Act 1990

Town and Country Planning (General Development Procedure) Order 1996

Re: P/2025/0773, PLAS GORORAU, ELLICE WAY, WREXHAM TECHNOLOGY PARK, WREXHAM, LL13 7YY

CODI STRWYTHUR PLASTIG WEDI'I ATGYFNERTHU Â GWYDR A SLABIAU CONCRIT CYSYLLTIEDIG I GARTREFU UNED TRIN AER / ERECTION OF GLASS REINFORCED PLASTIC STRUCTURE AND ASSOCIATED CONCRETE SLAB TO HOUSE AIR HANDLING UNIT

INF24 - DUST MANAGEMENT (SCHEME NOT REQUIRED BY CONDITION)

The Applicant is advised that under the dust from construction and / or demolition activities can be judged to be causing a statutory nuisance to neighbouring properties. A legal notice can be served requiring that any dust nuisance is abated, and failure to comply with the requirements of the notice can result in prosecution. The applicant should contact the Council's Environmental Health & Housing Standards Team on healthandhousing@wrexham.gov.uk or 01978 292040 for further advice and information.

INF23 - BURNING OF WASTE

Burning of waste generated from construction activities is not considered to be an appropriate method of disposal and action may be taken as follows:

- Under the Environmental Protection Act 1990 anyone found disposing of construction site waste by burning is likely to be in breach of their duty of care with regard to waste disposal;

- Under the same Act an abatement notice may be served where smoke is judged to be causing a nuisance to neighbouring properties. Failure to comply with the requirements of the notice can result in prosecution;

- Under the Clean Air Act 1993 it is an offence for a commercial activity to burn anything that gives rise to dark smoke.

To prevent offences under the above named Acts there should be no bonfires on the site, to include the prohibition of the burning of cleared vegetation. The applicant should contact the Council's Environmental Health & Housing Standards Team on healthandhousing@wrexham.gov.uk or 01978 292040 for further advice and information.

INF22 – MINOR DEMOLITION CONSTRUCTION NOISE

All works in relation to the implementation of this permission, including deliveries to and /or leaving the site, should be undertaken only between the hours of 07.30 to 18.00 Monday to Friday, 08.00 to 14.00 on a Saturday, and at no time on a Sunday or a Bank Holiday. Outside these times, any works which are audible beyond the site boundary have the potential to cause unreasonable disturbance to neighbouring premises.

The applicant is advised that the Council has the option to control construction noise by serving a Control of Pollution Act 1974, Section 60 Notice where deemed necessary, and failure to comply with such a Notice can result in prosecution.

The applicant is further advised that any complaints received relating to noise of any type from the development may also be investigated using the Council's Standardised Procedure for Dealing with Noise Nuisance Complaints. This is done under the Statutory Nuisance provisions provided within the Environmental Protection Act 1990, and legal action may be taken where appropriate.

The applicant must adhere to the times given above wherever possible. If, however, there are urgent or unavoidable circumstances requiring work outside of the specified times, permission to proceed may be sought by contacting Environmental Health & Housing Standards at healthandhousing@wrexham.gov.uk or 01978 292040. Please use the same contact details for any other enquiries regarding construction / demolition site noise.

Environmental Protection - No Comments

It is noted that the proposal is for a structure to house an air handling unit. As residential properties are approx. 50 metres from the proposed aera this section has concerns about a noise nuisance being caused to them.

I therefore recommend that the applicant be asked to provide the sound pressure levels associated with the proposed unit/s and the attenuation properties of the proposed structure. Alternatively, the applicant may commission an acoustic report in which case they are advised to contact healthandhousing@wrexham.gov.uk to agree a suitable scheme for the report. I recomend that this information be provided predetermination.

Following the provision of this information this section will then be able to provide an informed recommendation.

……

Head of Service Public Protection