

From: Jake MacMillan
Sent: 14 December 2023 11:22
To: Matthew Phillips <Matthew.Phillips@wrexham.gov.uk>
Subject: RE: P/2023/0776

Hi Matthew,

No problem, please see the below:

- the environmental permit for the associated wastewater treatment works has been reviewed against revised conservation objectives for water quality; [I can confirm the environmental permit has been reviewed against revised conservation objectives for water quality.](#)
- there is capacity in place to accommodate the additional wastewater in compliance with revised permit limits; [I can confirm there is capacity to accommodate the additional wastewater in compliance with the revised permit limit at Five Fords wwtw](#)
- the sewer network and associated WwTW has the hydraulic capacity for new connections without leading to an increase in the environmental impact of storm overflows. [I can confirm that the public sewerage network has hydraulic capacity for the increase in foul flows generated.](#)

Best regards,



Jake MacMillan

Development Planning Officer | Developer Services
Dŵr Cymru Welsh Water



T: 0800 917 2652 | E: 45xxx | M: 07557860559



A: PO Box 3146, Cardiff, CF30 0EH



W: dwrcymru.com



E: developer.services@dwrcymru.com

If we've gone the extra mile to provide you with excellent service, let us know. You can nominate an individual or team for a Diolch award through our [website](https://www.dwrcymru.com/en/Diolch-Awards.aspx). <https://www.dwrcymru.com/en/Diolch-Awards.aspx>