

FAO Sharon Holman

02/04/2019

Dear Sharon,

TOWN AND COUNTRY PLANNING ACT 1990
DEDDF CYNLLUNIO GWLAD A THREF 1990

BWRIAD / PROPOSAL:
Construction Of Timber Framed Building For Use As Classroom
LLEOLIAD / LOCATION:
Homestead Nursery Old Wrexham Road Gresford Wrexham

Thank you for consulting Natural Resources Wales (NRW) about the above, which was received on 12/03/2019.

NRW has no objection to the proposal. However, we would provide the following advice:

Protected Species

We note that there is no information about protected species with the application and, therefore, are assuming that your Authority has screened the application and concluded that there is not a reasonable likelihood of protected species being present.

Please do not hesitate to contact us if you require further information or clarification on any of the above.

Our comments above only relate specifically to matters that are listed in our 'Consultation Topics' document (September 2018) which is published on our website: (<https://cdn.naturalresources.wales/media/686847/dpas-consultation-topics-august-2018-eng.pdf?mode=pad&rnd=131819256840000000>). We have not considered potential effects on other matters and do not rule out the potential for the proposed development to affect other interests, including environmental interests of local importance.

Advice to Applicant

Foul Drainage

The developer/applicant should ensure that the existing septic tank has sufficient capacity to accommodate any increase in flows from the proposed development. The Applicant should note, it is a legal requirement to apply for an environmental permit or register an exemption with us. Septic tanks and small sewage treatment works may be registered as exempt from the requirement to obtain an environmental permit if certain criteria are met. Please note, should a permit be required, further information may be required as part of that application and the Applicant is therefore advised to hold pre-application discussions with our Permitting Team on 0300 065 3000, at the earliest opportunity, to try to ensure that there is no conflict between any planning permission granted and the permit requirements. If the Applicant already holds an exemption / permit, they should check whether the proposed increase in flows would require a further application to be made for a new / varied permit. It is important to note that a grant of planning permission does not guarantee that a permit will be granted, should a proposal be deemed to be unacceptable (either because of environmental risk or because upon further investigation, a connection to mains sewer was feasible). The Applicant should ensure that they have all the required permissions, consents, permits and any other approvals in place prior to commencement of works on the site.

More information, including a step by step guide to registering and the relevant application forms are available on our [website](#). Where private sewage treatment/disposal facilities are utilised, they must be installed and maintained in accordance with British Standards 6297 and Approved Document H of the Building Regulations. We also refer the Applicant to Guidance for Pollution Prevention 4 on the [NetRegs website](#), which provides further information.

Pollution Prevention

All works at the site must be carried out in accordance with PPG6: 'Working at construction and demolition sites' which are available on the following website:

<http://www.netregs.org.uk/environmental-topics/pollution-prevention-guidelines-ppgs-and-replacement-series/guidance-for-pollution-prevention-gpps-full-list/>

Waste produced during construction

Waste produced during the construction phase of your development must be dealt with appropriately and be in line with all relevant waste legislation including Duty of Care Regulations and Hazardous Waste Regulations. As part of your waste duty of care you must classify the waste produced:

- before it is collected, disposed of or recovered
- to identify the controls that apply to the movement of the waste
- to complete waste documents and records
- to identify suitably authorised waste management options
- to prevent harm to people and the environment.

Any waste removed from site will be subject to waste management controls. The links below provide information on how to classify waste and register as a waste carrier or hazardous waste producer:

<https://naturalresources.wales/permits-and-permissions/waste/?lang=en>

<https://naturalresources.wales/permits-and-permissions/waste/waste-permits/?lang=en>

Further guidance can be found on the GOV website here:

<https://www.gov.uk/managing-your-waste-an-overview/duty-of-care>

Bedrock

The proposed development is in an area of bedrock aquifer. This designation is consistent with the Water Framework Directive and reflects the importance of aquifers in terms of groundwater as a resource (drinking water supply) and also their role in supporting surface water flows and wetland ecosystems.

In the event that surface water from the development discharges to ground, we refer the developer to the Groundwater Protection: Principles and Practice (Environment Agency, 2013) Position Statements. We refer the developer to the Environment Agency 'Approach to groundwater protection' position statements which have been adopted by Natural Resources Wales. In particular the developer should be aware of the advice under Position Statements G13 (sustainable drainage systems) which applies to this development:

https://www.gov.uk/government/uploads/system/uploads/attachment_data/file/658135/LIT_7660.pdf

Landfill

According to our records the proposed development site is located near to land that is, or has been, used for the deposition of waste material. We would therefore advise you to consult with the local authority's Environmental Health and Building Control Departments, as they may hold detailed records, and may wish to make appropriate recommendations in respect of landfill gas investigation/remedial work. The developers should be made aware of the existence of the landfill site(s) so that they can decide whether or not to make their own investigations into the presence of landfill gas. It should also be noted that Waste Management Paper 27 states "It has been found that many sites which have taken only supposedly 'inert' waste have produced gas".

The applicant should be advised that, in addition to planning permission, it is their responsibility to ensure that they secure all other permits/consents relevant to their development.

Yn gywir / Yours sincerely,

Daniel Davies

Daniel Davies

Cynghorydd Cynllunio Datblygu / Development Planning Advisor

Cyfoeth Naturiol Cymru / Natural Resources Wales