

MEMORANDUM



From: Ian Jones Public Protection
Service Manager

To: David Williams Planning
Control Manager

Our Ref:

Your Ref: P/2021/0592

Date: 02-07-2021

Town and Country Planning Act 1990

Town and Country Planning (General Development Procedure) Order 1996

Re: P/2021/0592, KRONOSPAN LTD HOLYHEAD ROAD CHIRK WREXHAM

RHYDDHAU AMOD 04 (DEUNYDDIAU) A 05 (SWN) O BENDERFYNIAD APEL
APP/H6955/A/19/3227571 (P/2018/0551) / DISCHARGE OF CONDITIONS 04
(MATERIALS) AND 05 (NOISE) OF APPEAL DECISION APP/H6955/A/19/3227571
(P/2018/0551)

ZP05 - NOISE GENERATION - BS4142 REQUIRED

The provided details confirm that an Rw rating of 32dB will be achieved with the chosen cladding material which meets the recommendation in the NVC report (Report No. : R17.0506/1/DRK Date: 12th June 2018) and I therefore recommend that the condition relating to the OSB Manufacturing Facility Building Extension be discharged. Note: only as it applies to the Building Extension and NOT to the New Building where a higher Rw is recommended.

.....
Head of Planning and Regulatory