

Cerys Jones

From: Sharon Holman
Sent: 17 June 2021 10:06
To: planning_admin
Subject: RE: P/2020/0430 - Westerdale

Civ - add info web

-----Original Message-----

From: Andy Jones <ajones@coopers.co.uk>
Sent: 17 June 2021 09:56 AM
To: Dafydd Edwards <dafydd@blueprintarchitectural.com>
Cc: Sharon Holman <Sharon.Holman@wrexham.gov.uk>
Subject: RE: P/2020/0430 - Westerdale

Hi Sharon

Sorry for the delay responding.

Yes, we are now proposing to connect into the surface water sewer as a gravity connection into the highway drain is not possible. There is a substantial fall on Maes Y Ficerdy which will allow for a gravity connection routed as shown on the attached drawing.

This has now been agreed with Welsh Water. Please see attached correspondence.

Regards

Andy Jones
Senior Infrastructure Engineer
COOPERS
Park House, Sandpiper Court, Chester Business Park, Chester, CH4 9QU

: (01244) 684910 : Direct Dial No. (01244) 684933
☎: (01244) 684911
: ajones@coopers.co.uk
Web: <http://www.coopers.co.uk>