RSA Ref No : 2025-08 Cefn-y-Bedd RSA1 – Revision 0

RSA Stage : 1

RSA Auditors : Sevenairs Consulting Ltd

Response By: Axis

Paragraph No. in RSA Report	Brief Description of Issue	Problem Accepted (Yes/No)	Recommended Measure Accepted (Yes/No)	Alternative Measure / Design Team Response
A-01	Fences – Lack of barrier protection to the drainage ditch may increase the risk that pedestrians or other users enter the ditch and sustain injuries or drown	Yes	Yes	Rev G of Drawing Number 3034-01-D02 includes a note to illustrate the intention to install a suitable protective barrier / guardrail to be added at the interface between the new footpath and ditch, as per the RSA recommendation. A suitable protective barrier / guardrail specificaiton / detail will be identified at the detailed desing stage and installed as per the design.