

Ein cyf/Our ref: CAS-292772-H9P0
Eich cyf/Your ref: P/2022/0960

Wrexham County Borough Council
The Guildhall
Wrexham
LL11 1AY

Dyddiad/Date: 24 November 2025

Annwyl Syr/Madam/Dear Sir/Madam,

BWRIAD/PROPOSAL: Demolition of rear 20th century extensions to public house, partial rebuild and refurbishment of building and conversion to two dwellings and erection of 3 new dwellings.

LLEOLIAD/LOCATION: The Dymock Arms, Overton Road, Penley, Wrexham, LL13 0LS

Thank you for consulting Cyfoeth Naturiol Cymru (CNC)/Natural Resources Wales (NRW) about the additional information regarding the aboveabove, which we received on 11 November 2025.

We continue to have concerns with the application as submitted. To overcome these concerns, further consideration is required regarding foul drainage. Further details are provided below.

Protected sites – foul drainage

We note the application site is within the catchment of the River Dee and Bala Lake Special Area of Conservation (SAC). In line with our [Advice to Planning Authorities for Planning Applications Affecting Nutrient Sensitive River Special Areas of Conservation \(22 October 2025\)](#), under the Habitats Regulations, Planning Authorities must consider the impact of proposed developments on water quality within SAC river catchments.

The proposed development could potentially lead to an increase of phosphorus load from the receiving wastewater treatment works into the River Dee and Bala Lake Special Area of Conservation. The majority of the River Dee catchment in Wales is currently failing to meet water quality targets for phosphorus. The nutrient impacts of new connections need to be considered on a case-by-case basis within the Habitats Regulations Assessment process. Whilst NRW permitting service has completed a Review of Water Company Discharge Permits we are currently undertaking further data analysis for the River Dee following a number of enquiries and questions from stakeholders and several ongoing

Appeals. We will be able to provide further advice to your Authority once we have concluded the review.

We also refer you to our [Advice](#) and the section titled "*Can chemical pre-treatment be used to enable connection to a public sewer where phosphorus constraints apply?*"

Protected Species

We note that the information submitted in support of the above application (Preliminary Ecological Appraisal and Preliminary Roost Assessment by Arbtech 23/09/2022) has identified that bats are unlikely to be using the application site. We therefore have no comments to make on the application as submitted in respect of bats.

We recommend that you discuss the need to secure further measures/ avoidance measures with your internal ecological advisor.

Other Matters

The advice in this letter relates to matters which are included on our [consultation topics list](#). We do not rule out the potential for the proposed development to affect other environmental interests that are not included on this list.

We advise the applicant that, in addition to planning permission, it is their responsibility to ensure they secure all other permits/consents/licences relevant to their development. Please refer to our [website](#) for further details.

If you have any queries on the above, please do not hesitate to contact us.

Yn gywir / Yours faithfully,

Rhys Jones

Cynghorydd - Cynllunio Datblygu/Advisor - Development Planning
Cyfoeth Naturiol Cymru/Natural Resources Wales

E-bost/E-mail: northplanning@cyfoethnaturiolcymru.gov.uk

Croesewir gohebiaeth yn Gymraeg a byddwn yn ymateb yn Gymraeg, heb i hynny arwain at oedi./Correspondence in Welsh is welcomed, and we will respond in Welsh without it leading to a delay.