Ein cyf/Our ref: CAS-294208-M5J2
Eich cyf/Your ref: P/2025/0851

Wrexham County Borough Council
The Guildhall
Wrexham
LL11 1AY

Dyddiad/Date: 15 December 2025

Annwyl Syr/Madam/Dear Sir/Madam,

BWRIAD/PROPOSAL: CHANGE OF USE OF BUILDING FROM HOLIDAY LET TO ANNEXE TO MAIN BUILDING

LLEOLIAD/LOCATION: CRAIGNANT WARRANT, SELATTYN, OSWESTRY, SY10 7NS

Thank you for consulting Cyfoeth Naturiol Cymru (CNC)/Natural Resources Wales (NRW) about the above, which we received on 27 November 2025.

We have no objection to the proposed development as submitted and provide the following advice.

Protected Sites and Foul Drainage

We note the application site is within the catchment of the River Dee and Bala Lake Special Area of Conservation (SAC). In line with our Advice to Planning Authorities for Planning Applications Affecting Nutrient Sensitive River Special Areas of Conservation (22 October 2025), under the Habitats Regulations, Planning Authorities must consider the impact of proposed developments on water quality within SAC river catchments. We therefore advise you to consider whether the proposals, as submitted, would increase the volume of foul discharge from the site in planning terms.

We note the application, as submitted, proposes a change of use from holiday let to granny annexe. You may wish to consider whether this development proposal would result in the creation of independent living accommodation, a separate planning unit and/or whether the use can no longer said to be ancillary to the main residence. In this respect, we refer you to our Advice and the section titled '*What does this mean for domestic extensions*?'

Ultimately it is a matter of judgment for you, as Competent Authority, to satisfy yourselves that the proposed development will not result in a significant effect on the SAC.

We note, as stated on the application form, no changes will be made to the connection to the existing septic tank on site.

Applicants operating a private sewerage system need *either* to apply to us for an environmental permit *or* register with us for an exemption from the permit requirement. Septic tanks and small sewage treatment works that meet certain criteria may be registered as exempt.

A step by step guide to registering an exemption can be found on our website.

If the septic tank or private sewage treatment system is not eligible for an exemption, the Applicant will need to apply for an environmental permit, further details can be found here. Should a permit be required further information may be needed as part of that application process. The Applicant is therefore advised to contact us for pre-application advice at the earliest opportunity to try to ensure that there is no conflict between any planning permission granted and the permit requirements. Further details on how to access our pre-application advice service can be found here.

It is important to note that a grant of planning permission does not guarantee that a permit will be granted. A proposal may be deemed unacceptable either because of environmental risk or because upon further investigation, a connection to mains sewer was feasible. Applicants are encouraged to ensure they have all the required permissions, consents, permits and any other approvals in place prior to commencement of works on the site.

Where private sewage treatment/disposal facilities are utilised, they must be installed and maintained in accordance with British Standard 6297 and Approved Document H of the Building Regulations. We also refer the Applicant to Guidance for Pollution Prevention 4 on the NetRegs website, which provides further information.

Other Matters

The advice in this letter relates to matters which are included on our consultation topics list. We do not rule out the potential for the proposed development to affect other environmental interests that are not included on this list.

We advise the applicant that, in addition to planning permission, it is their responsibility to ensure they secure all other permits/consents/licences relevant to their development. Please refer to our website for further details.

If you have any queries about the above, please do not hesitate to contact us.

Yn gywir / Yours faithfully,

Pauline Gallagher Brown
Cynghorydd - Cynllunio Datblygu/Advisor - Development Planning
Cyfoeth Naturiol Cymru/Natural Resources Wales

E-bost/E-mail: northplanning@cyfoethnaturiolcymru.gov.uk

Croesewir gohebiaeth yn Gymraeg a byddwn yn ymateb yn Gymraeg, heb i hynny arwain at oedi./Correspondence in Welsh is welcomed, and we will respond in Welsh without it leading to a delay.