Dŵr Cymru
Welsh Water

Developer Services
PO Box 3146
Cardiff
CF30 0EH

Tel: +44 (0)800 917 2652
Fax: +44 (0)2920 740472
E.mail: developer.services@dwrcymru.com

Gwasanaethau Datblygu
Blwch Post 3146
Caerdydd
CF30 0EH

Ffôn: +44 (0)800 917 2652
Ffacs: +44 (0)2920 740472
E.bost: developer.services@dwrcymru.com

Wrexham County Council
16 Lord Street
WREXHAM
LL11 1LG

Date: 23/12/2025
Our Ref: PLA0092314
Your Ref: P/2025/0939

Dear Sir/Madam

Grid Ref: SJ194351 319473 335241
Site: Pont Y Meibion Tregeiriog Llangollen
Development: CONVERSION OF BARN TO HOLIDAY LET, CONVERSION OF OUTBUILDING TO OFFICE, ALTERATIONS TO FARMHOUSE INCLUDING SINGLE STOREY SIDE EXTENSION

We refer to your planning consultation relating to the above site, and we can provide the following comments in respect to the proposed development.

Having reviewed the details submitted we can provide the following comments.

PUBLIC SEWERAGE NETWORK

We note that the proposal would dispose of foul via alternative means to the main sewer. We advise that the applicant seek advice from the Natural Resources Wales and/or the Building Regulations Authority as the regulatory body for this method of drainage.

SURFACE WATER DRAINAGE

The application form identifies that surface water would be disposed via soakaways. Accordingly, we provide the following comments, based on the information provided to us at this stage.

As of 7th January 2019, this proposed development is subject to Schedule 3 of the Flood and Water Management Act 2010. The development therefore requires approval of Sustainable Drainage Systems (SuDS) features, in accordance with the 'Statutory standards for sustainable drainage systems – designing, constructing, operating and maintaining surface water drainage systems'. As highlighted in these standards, the developer is required to explore and fully exhaust all surface water drainage options in accordance with a hierarchy preferring infiltration (PL2) and, where infiltration is not possible, disposal to a surface water body (PL3), in liaison with the Lead Local Flood Authority and/or Natural Resources Wales, or surface water sewer or highway drain (PL4) in liaison with the riparian owner and/or Local Highways Authority.

glas
Glas Cymru Cyfyngedig

Welsh Water is owned by Glas Cymru – a 'not-for-profit' company.
Mae Dŵr Cymru yn eiddo i Glas Cymru – cwmni 'nid-er-elw'.

We welcome correspondence in Welsh and English

Dŵr Cymru Cyf, a limited company registered in Wales no 2366777. Registered office: Pentwyn Road, Nelson, Treharris, Mid Glamorgan CF46 6LY

Rydym yn croesawu gohebiaeth yn y Gymraeg neu yn Saesneg

Dŵr Cymru Cyf, cwmni cyfyngedig wedi'i gofrestru yng Nghymru rhif 2366777. Swyddfa gofrestredig: Heol Pentwyn Nelson, Treharris, Morgannwg Ganol CF46 6LY.

Please note, DCWW is a statutory consultee to the SAB application process and will provide comments to any SuDS proposals by response to SAB consultation. Please refer to further detailed advice relating to surface water management included in our attached Advice & Guidance note and our Developer Services website at https://developers.dwrcymru.com/en/help-advice/regulation-to-be-aware-of/sustainable-drainage-systems.

In the absence of an accompanying surface water drainage strategy, it is recommended that the developer engage in consultation with the Council, as the determining SuDS Approval Body (SAB), in relation to their proposals for SuDS features. Please be advised that due to capacity constraints with the downstream public sewerage network, under no circumstances would we allow surface water runoff highway run-off from the proposed development to communicate directly or indirectly with the public combined sewerage system. In addition, please note, no amount of land drainage run-off is permitted to discharge directly or indirectly into the public sewerage system.

Advisory

In accordance with Planning Policy Wales (Edition 12) and Technical Advice Note 12 (Design), the applicant is advised to take a sustainable approach in considering water supply in new development proposals, including utilising approaches that improve water efficiency and reduce water consumption. We would recommend that the applicant liaises with the relevant Local Authority Building Control department to discuss their water efficiency requirements.

The proposed development may be subject to Schedule 3 of the Flood and Water Management Act 2010. The development therefore may require approval of Sustainable Drainage Systems (SuDS) features, in accordance with national standards, and is strongly recommended that the developer engage in pre-application consultation with the Local Authority, as the relevant SuDS Approval Body (SAB), in relation to their proposals for SuDS features. Please note, Dwr Cymru Welsh Water is a statutory consultee to the SAB application process and will provide comments to any SuDS proposals by response to SAB consultation.

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at **developer.services@dwrcymru.com**

Please quote our reference number in all communications and correspondence.

Yours faithfully,

Olivia Davis
Development Planning Officer
Developer Services

glas
Glas Cymru Cyfyngedig

Welsh Water is owned by Glas Cymru – a 'not-for-profit' company.
Mae Dŵr Cymru yn eiddo i Glas Cymru – cwmni 'nid-er-elw'.

We welcome correspondence in Welsh and English

Dŵr Cymru Cyf, a limited company registered in Wales no 2366777. Registered office: Pentwyn Road, Nelson, Treharris, Mid Glamorgan CF46 6LY

Rydym yn croesawu gohebiaeth yn y Gymraeg neu yn Saesneg

Dŵr Cymru Cyf, cwmni cyfyngedig wedi'i gofrestru yng Nghymru rhif 2366777. Swyddfa gofrestredig: Heol Pentwyn Nelson, Treharris, Morgannwg Ganol CF46 6LY.