Dŵr Cymru
Welsh Water

Developer Services
PO Box 3146
Cardiff
CF30 0EH

Tel: +44 (0)800 917 2652
Fax: +44 (0)2920 740472
E.mail: developer.services@dwrcymru.com

Gwasanaethau Datblygu
Blwch Post 3146
Caerdydd
CF30 0EH

Ffôn: +44 (0)800 917 2652
Ffacs: +44 (0)2920 740472
E.bost: developer.services@dwrcymru.com

Wrexham County Council
16 Lord Street
WREXHAM
LL11 1LG

Date: 236/01/2026
Our Ref: PLA0087954
Your Ref: P/2025/0430

Dear Sir/Madam

Grid Ref: SJ383493 338739 349209
Site: Land at Oak Road, Wrexham Industrial Estate, Wrexham
Development: Proposed employment unit and new vehicular access, car and HGV parking, servicing and storage area, landscaping and ancillary development.

Please accept this letter as an update to our previous '*holding response*' (PLA0087954) dated the 23/06/2025 for the above planning application.

We can confirm that subsequent discussions have since taken place. In this regard, a draft scope for an easement width of a maximum 16 metres (8metres either side of the centreline) of the existing DCWW combined foul sewer at the site has been agreed 'in principle' with the applicant.

It is anticipated that further refinements to this maximum easement width will take place within the forthcoming 3 month period, following imminent additional site-specific survey work to take place. We will provide a separate update for the completion of the easement details to you. Our standard approach, unless expressly authorised, sets out no works to be undertaken within an agreed easement area and as such, proposed new developments should ensure alignment.

In light of the above, our previous 'holding response' can be updated with the following comments provided for the proposal:

FOUL SEWER
The proposed development site is located in the catchment of a public sewerage system which drains to Five Fords Wastewater Treatment Works (WwTW) and ultimately discharges to a river Special Area of Conservation (SAC). We would advise that this WwTW has a phosphorus consent limit and is currently seeking to comply with the 95% quartile for its flow passed forward (FPF) performance, at the time of this consultation. In addition, we have considered the impact of foul flows generated by the proposed development and concluded that flows can be accommodated within the immediate public sewerage system.

glas
Glas Cymru Cyfyngedig

Welsh Water is owned by Glas Cymru – a 'not-for-profit' company.
Mae Dŵr Cymru yn eiddo i Glas Cymru – cwmni 'nid-er-elw'.

We welcome correspondence in Welsh and English

Dŵr Cymru Cyf, a limited company registered in Wales no 2366777. Registered office: Pentwyn Road, Nelson, Treharris, Mid Glamorgan CF46 6LY

Rydym yn croesawu gohebiaeth yn y Gymraeg neu yn Saesneg

Dŵr Cymru Cyf, cwmni cyfyngedig wedi'i gofrestru yng Nghymru rhif 2366777. Swyddfa gofrestredig: Heol Pentwyn Nelson, Treharris, Morgannwg Ganol CF46 6LY.

No problems are envisaged with the Waste Water Treatment Works for the treatment of domestic discharges from this site.

SURFACE WATER

As of 7th January 2019, this proposed development may be subject to Schedule 3 of the Flood and Water Management Act 2010. In the event this proposed development amounts to a total impermeable area of 100sqm or more, approval of Sustainable Drainage Systems (SuDS) features will be required in accordance with the 'Statutory standards for sustainable drainage systems – designing, constructing, operating and maintaining surface water drainage systems'. It would therefore be recommended that the developer engage in consultation with Wrexham County Borough Council, as the determining SuDS Approval Body (SAB), in relation to their proposals for SuDS features. Please note, Dwr Cymru Welsh Water is a statutory consultee to the SAB application process and will provide comments to any SuDS proposals by response to SAB consultation.

A draft SUDS application is advised to accompany this current planning application, and the approach maximises the potential for controlling surface water removal at the site/adjoining land. No SUDS or land/highway drainage features should lie within the protection zones of any existing/diverted public sewers.

ASSET PROTECTION

As advised during the PAC stage, this site is currently crossed by public sewers with their approximate positions being marked on the attached statutory public sewer record. In accordance with the Water Industry Act 1991, Dwr Cymru Welsh Water requires access to its apparatus at all times in order to carry out maintenance and repairs.

We would request that if you are minded to grant Planning Consent for the above development that the **Conditions and Advisory Notes** provided below are included within the consent to ensure no detriment to existing residents or the environment and to Dwr Cymru Welsh Water's assets.

Conditions

Condition 1

No surface water and/or land drainage shall be allowed to connect directly or indirectly with the public sewerage network.

Reason: To prevent hydraulic overloading of the public sewerage system, to protect the health and safety of existing residents and ensure no pollution of or detriment to the environment.

Condition 2

No development shall commence until details of the following are submitted and approved by the Local Planning Authority in consultation with DCWW:

- an updated proposed site layout with the final agreed DCWW easement for the protection of the public sewer.
- a method statement and risk assessment for the protection of the structural condition of the public sewer crossing the site.

The approved protection measures shall be implemented in full before any other development hereby permitted has commenced, and shall be retained at all times for the duration of the approved operations including the restoration works.

Reason: To ensure that the proposed development does not affect the integrity of the public sewerage system in the interests of public health and safety.

Condition 3

No buildings on the application site shall be brought into beneficial use until such time as reinforcement works to the local public sewerage system, into which the development shall drain, have been completed as identified in a Hydraulic Modelling Assessment and written confirmation of this has been issued to the Local Planning Authority by Dwr Cymru Welsh Water.

Reason: To prevent hydraulic overloading of the public sewerage system, to protect the health and safety of existing residents and ensure no pollution of or detriment to the environment

Advisory Notes

The applicant may need to apply to Dwr Cymru / Welsh Water for any connection to the public sewer under S106 of the Water industry Act 1991. If the connection to the public sewer network is either via a lateral drain (i.e. a drain which extends beyond the connecting property boundary) or via a new sewer (i.e. serves more than one property), it is a mandatory requirement to first enter into a Section 104 Adoption Agreement (Water Industry Act 1991). The design of the sewers and lateral drains must also conform to the Welsh Ministers Standards for Gravity Foul Sewers and Lateral Drains, and conform with the publication "Sewers for Adoption"- 7th Edition. Further information can be obtained via the Developer Services pages of www.dwrcymru.com.

The applicant is also advised that some public sewers and lateral drains may not be recorded on our maps of public sewers because they were originally privately owned and were transferred into public ownership by nature of the Water Industry (Schemes for Adoption of Private Sewers) Regulations 2011. The presence of such assets may affect the proposal. In order to assist us in dealing with the proposal the applicant may contact Dwr Cymru Welsh Water. Under the Water Industry Act 1991 Dwr Cymru Welsh Water has rights of access to its apparatus at all times.

In accordance with Planning Policy Wales (Edition 12) and Technical Advice Note 12 (Design), the applicant is advised to take a sustainable approach in considering water supply in new development proposals, including utilising approaches that improve water efficiency and reduce

water consumption. We would recommend that the applicant liaises with the relevant Local Authority Building Control department to discuss their water efficiency requirements.

As of 7th January 2019, this proposed development is subject to Schedule 3 of the Flood and Water Management Act 2010. The development therefore requires approval of Sustainable Drainage Systems (SuDS) features, in accordance with the 'Statutory standards for sustainable drainage systems – designing, constructing, operating and maintaining surface water drainage systems'. It is therefore recommended that the developer engage in consultation with Wrexham County Borough Council, as the determining

SuDS Approval Body (SAB), in relation to their proposals for SuDS features. Please note, Dwr Cymru Welsh Water is a statutory consultee to the SAB application process and will provide comments to any SuDS proposals by response to SAB consultation.

If the development will give rise to a new discharge (or alter an existing discharge) of trade effluent, directly or indirectly to the public sewerage system, then a Discharge Consent under Section 118 of the Water Industry Act 1991 is required from Dwr Cymru / Welsh Water. Please note that the issuing of a Discharge Consent is independent of the planning process and a consent may be refused although planning permission is granted.

The planning permission hereby granted does not extend any rights to carry out any works to the public sewerage or water supply systems without first having obtained the necessary permissions required by the Water industries Act 1991.

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at **developer.services@dwrcymru.com**

Please quote our reference number in all communications and correspondence.

Yours faithfully,

Olivia Davis
Lead Development Planning Officer
Developer Services