Dŵr Cymru
Welsh Water

Developer Services
PO Box 3146
Cardiff
CF30 0EH

Tel: +44 (0)800 917 2652
Fax: +44 (0)2920 740472
E.mail: developer.services@dwrcymru.com

Gwasanaethau Datblygu
Blwch Post 3146
Caerdydd
CF30 0EH

Ffôn: +44 (0)800 917 2652
Ffacs: +44 (0)2920 740472
E.bost: developer.services@dwrcymru.com

Wrexham County Council
16 Lord Street
WREXHAM
LL11 1LG

Date: 11/03/2026
Our Ref: PLA0093659
Your Ref: P/2026/0083

Dear Sir/Madam

Grid Ref: SJ286489 328655 349003
Site: Land Adjacent To 1 Wayside Cottages Aberoer
Development: CHANGE OF USE OF LAND AND SITING OF 5 CHALETS

We refer to your planning consultation relating to the above site, and we can provide the following comments in respect to the proposed development.

We acknowledge that the application seeks the change of use of the land for 5 x chalets.

We note that the method of surface water disposal has not been identified; and foul via 'other' method of disposal to the mains.

Foul

There is no public sewerage system in this immediate locality. We note that the proposal would dispose of foul has not been identified. As the proposal intends utilising an alternative to mains drainage for foul water, we advise that the applicant seek advice from the Natural Resources Wales and/or the Building Regulations Authority as the regulatory body for this method of drainage.

Surface Water

As of 7th January 2019, this proposed development may be subject to Schedule 3 of the Flood and Water Management Act 2010. The development therefore requires approval of Sustainable Drainage Systems (SuDS) features, in accordance with the 'Statutory standards for sustainable drainage systems – designing, constructing, operating and maintaining surface water drainage systems'. As highlighted in these standards, the developer is required to explore and fully exhaust all surface water drainage options in accordance with a hierarchy preferring infiltration (PL2) and, where infiltration is not possible, disposal to a surface water body (PL3), in liaison with the Lead Local Flood Authority and/or Natural Resources Wales, or surface water sewer or highway drain (PL4) in liaison with the riparian owner and/or Local Highways Authority.

Please note, DCWW is a statutory consultee to the SAB application process and will provide comments to any SuDS proposals by response to SAB consultation. Please refer to further detailed advice relating to surface water management included in our attached Advice & Guidance note and our Developer Services website at https://developers.dwrcymru.com/en/help-advice/regulation-to-be-aware-of/sustainable-drainage-systems.

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at **developer.services@dwrcymru.com**

Please quote our reference number in all communications and correspondence.

Yours faithfully,

Olivia Davis
Development Planning Officer
Developer Services

glas
Glas Cymru Cyfyngedig

Welsh Water is owned by Glas Cymru – a 'not-for-profit' company.
Mae Dŵr Cymru yn eiddo i Glas Cymru – cwmni 'nid-er-elw'.

We welcome correspondence in Welsh and English

Dŵr Cymru Cyf, a limited company registered in Wales no 2366777. Registered office: Pentwyn Road, Nelson, Treharris, Mid Glamorgan CF46 6LY

Rydym yn croesawu gohebiaeth yn y Gymraeg neu yn Saesneg

Dŵr Cymru Cyf, cwmni cyfyngedig wedi'i gofrestru yng Nghymru rhif 2366777. Swyddfa gofrestredig: Heol Pentwyn Nelson, Treharris, Morgannwg Ganol CF46 6LY.