[redacted]

[redacted]

Public Protection has reviewed the Noise Assessment (Peninsular Acoustics, November 2025) and accepts the assessment as the basis for determining likely noise impacts, subject to the following mitigation and verification requirements. The operator shall implement the measures below prior to commencement of full operations and shall maintain them for the lifetime of the operation.

Plant and attenuation

- All fixed and mobile plant shall be fitted with the attenuation measures assumed in the acoustic assessment (for example enclosures, silencers, internal lining). Plant shall be maintained in good working order to ensure attenuation performance is retained.

Building and barrier controls

- The shredding warehouse roller doors shall remain closed during normal operation except for controlled access events; roller doors shall be of the construction and sealing standard assumed in the acoustic assessment.

- A 3 metre imperforate barrier with a minimum surface density of 10 kg/m^2 shall be installed along the south and south-western boundary as shown in the acoustic assessment. The barrier shall be installed prior to full operation and maintained for the duration of the operations

Operational controls

- External tipping and handling shall be minimised and restricted to designated locations and times to reduce external impact. Where practicable tipping shall be undertaken internally or within enclosed areas.

- HGV movements shall be routed and managed to avoid sensitive facades; prolonged idling shall be prohibited. Delivery and handling activities that generate high noise levels shall be scheduled within the permitted hours of operation.

Hours of operation

- Operations shall be limited to the daytime hours modelled in the acoustic assessment unless otherwise agreed in writing with the LPA.

Vehicle alarms and vehicle controls

- Reversing alarms shall be low-impact types (broadband/white noise or directional alarms) and their use shall be minimized near sensitive receptors. Alternative measures (banksmen, reversing cameras) shall be used where practicable.

Would you like me to send the above as a memo or will the email be suffice.

Kind regards

[redacted]