MEMORANDUM

From:	Stacey Inglis Contaminated Land Officer	**To:**	Sarah Holman Planning Officer
Our Ref:	P/2026/0255	**Your Ref:**	P/2026/0255
Date:	26 May 2026	**No. of Pages:**	2

TOWN AND COUNTRY PLANNING ACT 1990

P/2026/0255 – DEMOLITION OF EXISTING DWELLING, ERECTION OF REPLACEMENT DWELLING AND CONVERSION OF 4 NO OUTBUILDINGS TO 4 NO DWELLINGS

GAMFORD HOUSE, GAMFORD LANE, ROSSETT, WREXHAM, LL12 0EW

The following report has been submitted with the planning application:

- Phase 1 Environmental Site Assessment Report, Gamford House, Rossett, Wrexham, Wales, LL12 0EW for Urban Development Ltd, by Enviro Solution, 17th December 2020

The phase 1 risk assessment is sufficient, and I concur with the findings of the report and the recommendation for intrusive investigation works. Therefore, to ensure that any potential contamination issues are adequately dealt with I would recommend that the following condition and note to applicant be applied to any future consent that may be granted.

Conditions

ZP01B CONTAMINATED LAND – PHASED INVESTIGATION
No development shall take place until a phased site investigation of the nature and extent of contamination has been carried out and submitted to and approved in writing by the Local Planning Authority. If any contamination is found during the site investigation, no part of the development shall commence until a scheme specifying the measures that will be taken to remediate the site to render it suitable for the development hereby permitted has been submitted to and approved in writing by the local planning authority. The site shall thereafter be remediated in accordance with the approved scheme. If during the course of development any contamination is found that has not been identified in the site investigation, no further development shall take place on those parts of the site where that contamination has been found until an additional scheme of remediation has been submitted to and approved in writing

by the local planning authority for those parts of the site. The relevant parts of the site shall thereafter be remediated in accordance with the additional scheme of remediation.

ZP02A VERIFICATION REPORT - CONTAMINATED LAND
Each part of the site subject to the remediation under the scheme(s) approved as part of condition @@ shall not be occupied/used until a Validation Report has been completed in respect of that part of the site and submitted to and approved in writing by the Local Planning Authority.

Informative

INF03 - SITE CONTAMINATION
Further advice on compliance with condition no. @@ may be obtained by contacting the Council's Contaminated Land Officer on 01978 298771 or 297773. Should the investigation identify contamination issues that may affect receptors other than the site users e.g. groundwater, then it is recommended that these works are also addressed in consultation with the Contaminated Land Officer prior to commencement of works on site.



……
Stacey Inglis
Contaminated Land Officer