Dŵr Cymru
Welsh Water

Developer Services
PO Box 3146
Cardiff
CF30 0EH

Tel: +44 (0)800 917 2652
Fax: +44 (0)2920 740472
E.mail: developer.services@dwrcymru.com

Gwasanaethau Datblygu
Blwch Post 3146
Caerdydd
CF30 0EH

Ffôn: +44 (0)800 917 2652
Ffacs: +44 (0)2920 740472
E.bost: developer.services@dwrcymru.com

Wrexham County
16
Lord Street
WREXHAM
LL11 1LG

Date: 10/06/2026
Our Ref: PLA0095736
Your Ref: P/2026/0313

Dear Sir/ Madam,

Grid Ref: SJ377496 337940 349710
Site: Ardagh Metal Beverage, Bridge Road, North Wrexham
Development: CHANGE OF USE OF BUILDING FROM CLASS B2 (GENERAL INDUSTRIAL) TO MIXED USE CLASS B2/B8 (WAREHOUSE AND PRODUCTION)

We refer to your planning consultation relating to the above site, and we can provide the following comments in respect to the proposed development.

The proposed development site is crossed by a public sewer with the approximate position being marked on the attached Statutory Public Sewer Record. Should circumstances change and the application proposes any operational development, including any new structures or increase in the roof area of the building, we must be re-consulted on this application.

Notwithstanding this, the application appears to rely on existing sewer connections and no new connections are to be made with the public sewerage system. Nonetheless, for the avoidance of doubt, we would request that the following **Condition and Advisory Notes** are included within the consent to ensure no detriment to existing residents or the environment and to Dwr Cymru Welsh Water's assets:

Condition

No surface water from any increase in the roof area of the building /or impermeable surfaces within its curtilage shall be allowed to drain directly or indirectly to the public sewerage system.

Reason: To prevent hydraulic overloading of the public sewerage system, to protect the health and safety of existing residents and ensure no pollution of or detriment to the environment.

Advisory Notes

The planning permission hereby granted does not extend any rights to carry out any works to the public

sewerage or water supply systems without first having obtained the necessary permissions required by the Water industries Act 1991. This means that any alterations to existing premises that result in the creation of additional premises or merging of existing premises must be constructed so that each of the premises is separately connected to the Company's water main and can be separately metered. Please contact our new connections team on 0800 917 2652 for further information.

If the development will give rise to a new discharge (or alter an existing discharge) of trade effluent, directly or indirectly to the public sewerage system, then a Discharge Consent under Section 118 of the Water Industry Act 1991 is required from Dwr Cymru / Welsh Water. Please note that the issuing of a Discharge Consent is independent of the planning process and a consent may be refused although planning permission is granted.

The applicant is also advised that some public sewers and lateral drains may not be recorded on our maps of public sewers because they were originally privately owned and were transferred into public ownership by nature of the Water Industry (Schemes for Adoption of Private Sewers) Regulations 2011. The presence of such assets may affect the proposal. In order to assist us in dealing with the proposal the applicant may contact Dwr Cymru Welsh Water to establish the location and status of the apparatus. Under the Water Industry Act 1991 Dwr Cymru Welsh Water has rights of access to its apparatus at all times.

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at **developer.services@dwrcymru.com**

Please quote our reference number in all communications and correspondence.

Yours faithfully,

Olivia Davis
Development Planning Officer
Developer Services