wrexham
COUNTY BOROUGH COUNCIL
CYNGOR BWRDEISTREF SIROL
wrecsam

MEMORANDUM

From: **Roger Mapleson**
Head of Service Public Protection

To: **Matthew Phillips**
Head of Service Planning Development

Our Ref:

Your Ref: **P/2025/0926**

Date: 24-06-2026

Town and Country Planning Act 1990

Town and Country Planning (General Development Procedure) Order 1996

Re: P/2025/0926, 17 CEIRIOG CLOSE, CHIRK, WREXHAM, LL14 5SB

GOSOD PWMP GWRES FFYNHONNELL AER / INSTALLATION OF AIR SOURCE HEAT PUMP

RPT1 - REPORT REVIEW

Public Protection has reviewed the proposal and reviewed the submitted document - Air Source Heat Pump Noise Level Calculateion Form. following this review raises no objection.

It is however recommended that the air source heat pump is installed in accordance with manufacturer guidance and incorporates appropriate anti-vibration measures to prevent transmission of structure-borne noise to the property.

……

Head of Service Public Protection