Ein cyf/Our ref: CAS-310834-S1S0
Eich cyf/Your ref: P/2024/1262

Wrexham County Borough Council
The Guildhall
Wrexham
LL11 1AY

Dyddiad/Date: 25 June 2026

Annwyl Syr/Madam/Dear Sir/Madam,

**Bwriad/Proposal: OUTLINE APPLICATION FOR ERECTION OF 3 DWELLINGS**

**Lleoliad/Location: Swn Y Gwynt, Cross Lane, Pentre Broughton, Wrexham, LL11 6AR**

Thank you for consulting Cyfoeth Naturiol Cymru/Natural Resources Wales (NRW) about the above, which we received on 10 June 2026.

We continue to have **concerns** with the application as submitted because inadequate information has been provided in support of the proposal. To overcome these concerns, you should seek further information from the applicant regarding **foul drainage**. If this information is not provided, we would object to this planning application. Further details are provided below.

# Protected sites – foul drainage

We note the application site is within the catchment of the River Dee and Bala Lake Special Area of Conservation (SAC). In line with our Advice to Planning Authorities for Planning Applications Affecting Nutrient Sensitive River Special Areas of Conservation, under the Habitats Regulations, Planning Authorities must consider the impact of proposed developments on water quality within SAC river catchments. We therefore advise you to consider whether the proposals, as submitted, would increase the volume of foul discharge from the site in planning terms.

We note that the Highway Supporting Statement by Cullis Architectural Design dated 11.09.2025 proposes two options for foul water disposal:

1. Pumped manhole system connecting to main sewer
2. Klargester BioDisc domestic sewage treatment plan.

However, it is unclear from the information submitted which option is being proposed for approval as part of this application. As you are aware, the site is within a sewered area.

Ultimately, the suitability of foul drainage arrangements for the proposed development is a matter for your Authority to determine. However, the installation of private sewage treatment facilities within publicly sewered areas is not normally considered environmentally acceptable because of the greater risk of failures leading to pollution of the water environment compared to public sewerage systems.

Section 6.6.21 of Planning Policy Wales states '*Any development discharging domestic sewage should connect to the foul sewer where it is reasonable to do so. Development proposing the use of non-mains drainage schemes will only be considered acceptable where connection to the main sewer is not feasible...*'

Government guidance on private sewerage in Welsh Government Circular 008/2018 stresses that the first presumption must be to provide a system of foul drainage discharging into a public sewer. Only where having taken into account the cost and/or practicability it can be shown to the satisfaction of the local planning authority that connection to a public sewer is not feasible, should non-mains foul sewage disposal solutions be considered.

We therefore advise the Applicant to either amend their proposals to ensure that the foul drainage is connected to the mains sewerage system or provide detailed evidence to demonstrate that it is not reasonable to connect.

The Applicant should thoroughly investigate the possibility of connecting to the foul sewer by taking the following steps:

- Approach the sewerage undertaker to reach an agreement for a connection to the foul sewer.
- If the sewerage undertaker refuses connection to the public sewer, request that they adopt the proposed treatment system.
- If the sewerage undertaker refuses both of the above, you must appeal the refusal with Ofwat.

For further details please see Natural Resources Wales / Private sewage treatment in an area with a public sewer

The Applicant should be aware that should a connection to the mains sewer not be feasible, they will also need to demonstrate that the proposal would not pose an unacceptable risk to the water environment. Welsh Government Circular 008/2018 advises that a full and detailed consideration be given to the environmental criteria listed under paragraph 2.6 of the Circular, in order to justify the use of private sewerage.

As stated above, we expect developers discharging domestic sewage to connect to the public foul sewer where it is reasonable to do so. We will not normally grant a discharge permit for a private sewage treatment system where it is reasonable to connect to the public foul sewer. We also expect discharges of trade effluent to connect to the public foul

sewer where it is reasonable to do so and subject to the sewerage undertaker granting a trade effluent consent or entering into a trade effluent agreement.

Furthermore, we refer you to the section in our Advice titled ‘What does this mean for development proposals involving connection to public wastewater treatment works’.

## Protected Species

We note that the information submitted in support of the above application (Ecological Impact Assessment at Swn y Gwynt, Cross Lanes, Pentre Broughton, Wrexham by Susan Worsfold dated 18th December 2024) has identified that bats are unlikely to be using the application site. We therefore have no comments to make on the application as submitted in respect of bats.

## Other matters

The advice in this letter relates to matters which are included on our consultation topics list. We do not rule out the potential for the proposed development to affect other environmental interests that are not included on this list.

We advise the applicant that, in addition to planning permission, it is their responsibility to ensure they secure all other permits/consents/licences relevant to their development. Please refer to our website for further details.

If you have any queries about the above, please do not hesitate to contact us.

Yn gywir / Yours faithfully,

**Rhys Jones**

Cynghorydd - Cynllunio Datblygu/Advisor - Development Planning

Cyfoeth Naturiol Cymru/Natural Resources Wales

E-bost/E-mail: neplanning@cyfoethnaturiolcymru.gov.uk

Croesewir gohebiaeth yn Gymraeg a byddwn yn ymateb yn Gymraeg, heb i hynny arwain at oedi./Correspondence in Welsh is welcomed, and we will respond in Welsh without it leading to a delay.