wrexham
COUNTY BOROUGH COUNCIL
CYNGOR BWRDEISTREF SIROL
wrecsam

MEMORANDUM

From: **Roger Mapleson**
Head of Service Public Protection

To: **Matthew Phillips**
Head of Service Planning Development

Our Ref:

Your Ref: **P/2026/0473**

Date: 24-07-2026

Town and Country Planning Act 1990

Town and Country Planning (General Development Procedure) Order 1996

Re: P/2026/0473, TELECOMMUNICATIONS MAST, PEN Y GRAIG, FRONCYSYLLTE, LLANGOLLEN, LL20 7RT

HYSBYSIAD YMLAEN LLAW AR GYFER UWCHRADDIO CYFARPAR TELATHREBU PRESENNOL/ PRIOR NOTIFICATION FOR UPGRADES TO EXISTING TELECOMS APPARATUS

RPT 2 - REPORT REQUIRED

(WCBC 53)

The proposal is for the installation of a backup generator. Due to the presence of residential receptors in close proximity to the application area this section requires acoustic data (including low frequency noise) to demonstrate there will be no loss of amenity to any sensitive receptor in the event the generator is used. The information provided should include whether any acoustic shielding forms part of the design and supporting details provided. Vibration details should also be provided to demonstrate that there will be no adverse impact.

Once this information has been provided this section will be able to respond to the consultation.

……

Head of Service Public Protection