Developer Services
PO Box 3146
Cardiff
CF30 0EH

Gwasanaethau Datblygu
Blwch Post 3146
Caerdydd
CF30 0EH

Tel / Ffôn: +44 (0)800 917 2652
Email / Ebost: developer.services@dwrcymru.com

Wrexham
16 Lord Street
Wrexham
LL11 1LG

Date: 4th August 2026
Our Ref: 1000951
Your Ref: P/2026/0443

Grid Ref: 334628,354827
Site: Clapper Lane Gresford, Wrexham, LL12 8RW
Development: Erection of a single storey modular building to provide accommodation for a Flying Start Childcare Expansion

We refer to your planning consultation relating to the above site, and we can provide the following comments in respect to the proposed development.

SEWERAGE

We can confirm capacity exists within the public sewerage network in order to receive the domestic foul only flows from the proposed development site.

We can advise that Gresford WwTW has a phosphate permit. You will need to discuss this matter further with the local planning authority.

The proposed development may be subject to Schedule 3 of the Flood and Water Management Act 2010. The development therefore may require approval of Sustainable Drainage Systems (SuDS) features, in accordance with national standards, and is strongly recommended that the developer engage in pre-application consultation with the Local Authority, as the relevant SuDS Approval Body (SAB), in relation to their proposals for SuDS features. Please note, Dwr Cymru Welsh Water is a statutory consultee to the SAB application process and will provide comments to any SuDS proposals by response to SAB consultation.

Conditions

No surface water from any increase in the roof area of the building /or impermeable surfaces within its curtilage shall be allowed to drain directly or indirectly to the public sewerage system.

We're not-for-profit. Every single penny we make goes back into looking after your water and environment. You can contact us in Welsh or English.

Rydym yn gwmni nid-er-elw. Mae pob ceiniog a wnawn yn mynd i ofalu am eich dŵr a'ch amgylchedd. Cysylltwch a ni yn Gymraeg neu'n Saesneg.

Dŵr Cymru Cyf (2366777)
A limited Company registered in Wales
Cwmni cyfyngedig wedi'i gofrestu yng Nghymru:
Linea, Fortran Road, St Mellons, Cardiff, CF3 0LT

Dŵr Cymru Welsh Water

Developer Services
PO Box 3146
Cardiff
CF30 0EH

Gwasanaethau Datblygu
Blwch Post 3146
Caerdydd
CF30 0EH

Tel / Ffôn: +44 (0)800 917 2652

Email / Ebost: developer.services@dwrcymru.com

Reason: To prevent hydraulic overloading of the public sewerage system, to protect the health and safety of existing residents and ensure no pollution of or detriment to the environment.

Advisory Notes

The applicant is advised that some public sewers and lateral drains may not be recorded on our maps; some sewers were originally privately owned and were transferred into public ownership by nature of the Water Industry (Schemes for Adoption of Private Sewers) Regulations 2011. The presence of such assets may affect the proposal. In order to assist us in dealing with the proposal the applicant may contact Dwr Cymru Welsh Water. Under the Water Industry Act 1991 Dwr Cymru Welsh Water has rights of access to its apparatus at all times.

The applicant may also need to apply to Dwr Cymru / Welsh Water for any connection to the public sewer under S106 of the Water industry Act 1991. If the connection to the public sewer network is either via a lateral drain (i.e. a drain which extends beyond the connecting property boundary) or via a new sewer (i.e. serves more than one property), it is now a mandatory requirement to first enter into a Section 104 Adoption Agreement (Water Industry Act 1991). The design of the sewers and lateral drains must also conform to the Welsh Ministers Standards for Gravity Foul Sewers and Lateral Drains, and conform with the publication "Sewers for Adoption"- 7th Edition. Further information can be obtained via the Developer Services pages of www.dwrcymru.com

In accordance with Planning Policy Wales (Edition 11) and Technical Advice Note 12 (Design), the applicant is advised to take a sustainable approach in considering water supply in new development proposals, including utilising approaches that improve water efficiency and reduce water consumption. We would recommend that the applicant liaises with the relevant Local Authority Building Control department to discuss their water efficiency requirements.

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at developer.services@dwrcymru.com. Please quote our reference number in all communications and correspondence.

We're not-for-profit. Every single penny we make goes back into looking after your water and environment. You can contact us in Welsh or English.

Rydym yn gwmni nid-er-elw. Mae pob ceiniog a wnawn yn mynd i ofalu am eich dŵr a'ch amgylchedd. Cysylltwch a ni yn Gymraeg neu'n Saesneg.

Dŵr Cymru Cyf (2366777)
A limited Company registered in Wales
Cwmni cyfyngedig wedi'i gofrestu yng Nghymru:
Linea, Fortran Road, St Mellons, Cardiff, CF3 0LT

Developer Services
PO Box 3146
Cardiff
CF30 0EH

Gwasanaethau Datblygu
Blwch Post 3146
Caerdydd
CF30 0EH

Tel / Ffôn: +44 (0)800 917 2652

Email / Ebost: developer.services@dwrcymru.com

Yours sincerely,

Developer Services

Dŵr Cymru Welsh Water

We're not-for-profit. Every single penny we make goes back into looking after your water and environment. You can contact us in Welsh or English.

Rydym yn gwmni nid-er-elw. Mae pob ceiniog a wnawn yn mynd i ofalu am eich dŵr a'ch amgylchedd. Cysylltwch a ni yn Gymraeg neu'n Saesneg.

Dŵr Cymru Cyf (2366777)
A limited Company registered in Wales
Cwmni cyfyngedig wedi'i gofrestu yng Nghymru:
Linea, Fortran Road, St Mellons, Cardiff, CF3 0LT