Developer Services
PO Box 3146
Cardiff
CF30 0EH

Gwasanaethau Datblygu
Blwch Post 3146
Caerdydd
CF30 0EH

Tel / Ffôn: +44 (0)800 917 2652
Email / Ebost: developer.services@dwrcymru.com

Wrexham
16 Lord Street
Wrexham
LL11 1LG

Date: 20th August 2026
Our Ref: 1001789
Your Ref: P/2026/0468

Grid Ref: 332334,349366
Site: Access Roads To Puleston Industrial Estates Felin Puleston, Wrexham, Wrexham, LL13 7RF
Development: Retrospective Planning Permission for Existing Extension

We refer to your planning consultation relating to the above site, and we can provide the following comments in respect to the proposed development.

We note that the method for disposal of foul and surface water is intended via the main sewer.

Foul Disposal

The proposed development site is located in the catchment of a public sewerage system which drains to Five Fords Wastewater Treatment Works (WwTW). We have considered the impact of foul flows generated by the proposed development and concluded that flows can be accommodated within the public sewerage system.

We would request that if you are minded to grant Planning Consent for the above development that the Conditions and Advisory Notes provided below are included within the consent to ensure no detriment to existing residents or the environment and to Dwr Cymru Welsh Water's assets.

Conditions

Condition 1 – Surface Water

No surface water from any increase in the roof area of the building /or impermeable surfaces within its curtilage shall be allowed to drain directly or indirectly to the public sewerage system.

Reason: To prevent hydraulic overloading of the public sewerage system, to protect the health and safety of existing residents and ensure no pollution of or detriment to the environment.

We're not-for-profit. Every single penny we make goes back into looking after your water and environment. You can contact us in Welsh or English.

Rydym yn gwmni nid-er-elw. Mae pob ceiniog a wnawn yn mynd i ofalu am eich dŵr a'ch amgylchedd. Cysylltwch a ni yn Gymraeg neu'n Saesneg.

Dŵr Cymru Cyf (2366777)
A limited Company registered in Wales
Cwmni cyfyngedig wedi'i gofrestu yng Nghymru:
Linea, Fortran Road, St Mellons, Cardiff, CF3 0LT

Developer Services
PO Box 3146
Cardiff
CF30 0EH

Gwasanaethau Datblygu
Blwch Post 3146
Caerdydd
CF30 0EH

Tel / Ffôn: +44 (0)800 917 2652

Email / Ebost: developer.services@dwrcymru.com

Advisory Notes

In accordance with Planning Policy Wales (Edition 12) and Technical Advice Note 12 (Design), the applicant is advised to take a sustainable approach in considering water supply in new development proposals, including utilising approaches that improve water efficiency and reduce water consumption. We would recommend that the applicant liaises with the relevant Local Authority Building Control department to discuss their water efficiency requirements.

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at developer.services@dwrcymru.com. Please quote our reference number in all communications and correspondence.

Yours sincerely,

Developer Services

Dŵr Cymru Welsh Water

We're not-for-profit. Every single penny we make goes back into looking after your water and environment. You can contact us in Welsh or English.

Rydym yn gwmni nid-er-elw. Mae pob ceiniog a wnawn yn mynd i ofalu am eich dŵr a'ch amgylchedd. Cysylltwch a ni yn Gymraeg neu'n Saesneg.

Dŵr Cymru Cyf (2366777)
A limited Company registered in Wales
Cwmni cyfyngedig wedi'i gofrestu yng Nghymru:
Linea, Fortran Road, St Mellons, Cardiff, CF3 0LT