The Coal Authority

200 Lichfield Lane
Mansfield
Nottinghamshire
NG18 4RG
T: 01623 637 119 (Planning Enquiries)
E: planningconsultation@coal.gov.uk
W: www.gov.uk/coalauthority

For the attention of: Jenni Perkins – Case Officer
Wrexham County Borough Council

[By email: planning@wrexham.gov.uk]

11 September 2026

Dear Jenni

Re: P/2026/0456

Change of use of land to a 3 pitch family gypsy & traveller site and erection of stables; land to the north of Brymbo Road, Bwlchgwyn, Wrexham, LL11 5TY

Thank you for your notification of 7 September 2026 seeking the views of the Coal Authority on the above.

The Coal Authority is a non-departmental public body sponsored by the Department for Energy Security and Net Zero. As a statutory consultee, the Coal Authority has a duty to respond to planning applications and development plans in order to protect the public and the environment in mining areas.

The Coal Authority response:

Despite the objections raised in our consultation response letters dated 12 September 2025 and 20 October 2025 to P/2025/0268, the application was refused permission, with none of the sited reasons for refusal relating to coal mining legacy.

Notwithstanding the above, and whilst in this instance those built development aspects of the proposals appear more significant when compared to those previously proposed, given

the protracted planning history and that fact that development within the zone of influence of the off-site mine entry would site within the parameters of our Exemption Criteria, the Coal Authority raises no objections, subject to the below recommendation.

The Coal Authority Recommendation to the LPA

As you will be aware, the Coal Authority's general approach in cases where development is proposed within the Development High Risk Area is to recommend that the applicant obtains coal mining information for the application site and submits a Coal Mining Risk Assessment to support the planning application.

However, and whilst a Coal Mining Risk Assessment does not appear to accompany the planning application, when considering both the nature of the proposals and the coal mining legacy of the site, the Coal Authority does not consider that a Coal Mining Risk Assessment would be proportionate in this particular instance and **do not object** to this planning application.

Notwithstanding the above, and the interests of public safety the Coal Authority would recommend that, should planning permission be granted for this proposal, the following wording is included as an Informative Note within the Decision Notice:

The proposed development lies within an area that has been defined by the Coal Authority as containing coal mining features at surface or shallow depth. These features may include: mine entries (shafts and adits); shallow coal workings; geological features (fissures and break lines); mine gas and former surface mining sites. Although such features are seldom readily visible, they can often be present and problems can occur, particularly as a result of new development taking place.

Any form of development over or within the influencing distance of a mine entry can be dangerous and raises significant land stability and public safety risks. As a general precautionary principle, the Coal Authority considers that the building over or within the influencing distance of a mine entry should be avoided. In exceptional circumstance where this is unavoidable, expert advice must be sought to ensure that a suitable engineering design which takes into account all the relevant safety and environmental risk factors, including mine gas and mine-water. Your attention is drawn to the Coal Authority Policy in relation to new development and mine entries available at:
www.gov.uk/government/publications/building-on-or-within-the-influencing-distance-of-mine-entries

Any intrusive activities which disturb or enter any coal seams, coal mine workings or coal mine entries (shafts and adits) requires a Coal Authority Permit. Such activities could include site investigation boreholes, excavations for foundations, piling activities, other ground works and any subsequent treatment of coal mine workings and coal mine entries for ground stability purposes. Failure to obtain permission to enter or disturb our property will result in the potential for court action.

If any coal mining features are unexpectedly encountered during development, this should be reported immediately to the Coal Authority on 0345 762 6848. Further information is available on the Coal Authority website at:
www.gov.uk/government/organisations/the-coal-authority

Please do not hesitate to contact me if you would like to discuss this matter further.

Yours sincerely

Chris MacArthur

Chris MacArthur *B.Sc.(Hons), DipTP, MRTPI*
Planning Liaison Manager

Disclaimer

The above consultation response is provided by The Coal Authority as a Statutory Consultee and is based upon the latest available coal mining data on the date of the response, and electronic consultation records held by The Coal Authority since 1 April 2013. The comments made are also based upon only the information provided to The Coal Authority by the Local Planning Authority and/or has been published on the Council's website for consultation purposes in relation to this specific planning application. The views and conclusions contained in this response may be subject to review and amendment by The Coal Authority if additional or new data/information (such as a revised Coal Mining Risk Assessment) is provided by the Local Planning Authority or the Applicant for consultation purposes.