Developer Services
PO Box 3146
Cardiff
CF30 0EH

Gwasanaethau Datblygu
Blwch Post 3146
Caerdydd
CF30 0EH

Tel / Ffôn: +44 (0)800 917 2652
Email / Ebost: developer.services@dwrcymru.com

Wrexham
16 Lord Street
Wrexham
LL11 1LG

Date: 1st October 2026
Our Ref: 1003521
Your Ref: P/2026/0531

Grid Ref: 333132,353229
Site: PLAS ACTON INDUSTRIAL ESTATE, PANDY, WREXHAM, WREXHAM, LL11 2UB
Development: CHANGE OF USE OF LAND TO CREATE CAR STORAGE AND PARKING AREA

We refer to your planning consultation relating to the above site, and we can provide the following comments in respect to the proposed development.

The proposal does not appear to seek a connection for foul disposal. We note that surface water will be disposed of via sustainable drainage systems.

Therefore to ensure there is no detriment to the public sewerage network we request that should you be minded to grant planning permission the following **Conditions and Advisory Notes** are included.

Conditions

No surface water and/or land drainage shall be allowed to connect directly or indirectly with the public sewerage network.

Reason: To prevent hydraulic overloading of the public sewerage system, to protect the health and safety of existing residents and ensure no pollution of or detriment to the environment.

Advisory Notes

In accordance with Planning Policy Wales (Edition 12) and Technical Advice Note 12 (Design), the applicant is advised to take a sustainable approach in considering water supply in new development proposals, including utilising approaches that improve water efficiency and reduce water consumption. We would recommend that the applicant liaises with the relevant Local Authority Building Control department to discuss their water efficiency requirements.

We're not-for-profit. Every single penny we make goes back into looking after your water and environment. You can contact us in Welsh or English.

Rydym yn gwmni nid-er-elw. Mae pob ceiniog a wnawn yn mynd i ofalu am eich dŵr a'ch amgylchedd. Cysylltwch a ni yn Gymraeg neu'n Saesneg.

Dŵr Cymru Cyf (2366777)
A limited Company registered in Wales
Cwmni cyfyngedig wedi'i gofrestu yng Nghymru:
Linea, Fortran Road, St Mellons, Cardiff, CF3 0LT

Developer Services
PO Box 3146
Cardiff
CF30 0EH

Gwasanaethau Datblygu
Blwch Post 3146
Caerdydd
CF30 0EH

Tel / Ffôn: +44 (0)800 917 2652

Email / Ebost: developer.services@dwrcymru.com

The applicant may need to apply to Dwr Cymru / Welsh Water for any connection to the public sewer under S106 of the Water industry Act 1991. If the connection to the public sewer network is either via a lateral drain (i.e., a drain which extends beyond the connecting property boundary) or via a new sewer (i.e., serves more than one property), it is now a mandatory requirement to first enter into a Section 104 Adoption Agreement (Water Industry Act 1991). The design of the sewers and lateral drains must also conform to the Welsh Ministers Standards for Gravity Foul Sewers and Lateral Drains and conform with the publication "Sewers for Adoption"- 7th Edition. Further information can be obtained via the Developer Services pages of www.dwrcymru.com

The planning permission hereby granted does not extend any rights to carry out any works permissions required by the Water industries Act 1991. Any alterations to existing premises resulting in the creation of additional premises or merging of existing premises must also be constructed so that each is separately connected to the Company's water main and can be separately metered. Please contact our new connections team on 0800 917 2652 for further information on water and sewerage connections.

The applicant is also advised that some public sewers and lateral drains may not be recorded on our maps of public sewers because they were originally privately owned and were transferred into public ownership by nature of the Water Industry (Schemes for Adoption of Private Sewers) Regulations 2011. The presence of such assets may affect the proposal. In order to assist us in dealing with the proposal the applicant may contact Dwr Cymru Welsh Water. Under the Water Industry Act 1991 Dwr Cymru Welsh Water has rights of access to its apparatus at all times.

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at developer.services@dwrcymru.com. Please quote our reference number in all communications and correspondence.

Yours sincerely,

Developer Services

Dŵr Cymru Welsh Water

We're not-for-profit. Every single penny we make goes back into looking after your water and environment. You can contact us in Welsh or English.

Rydym yn gwmni nid-er-elw. Mae pob ceiniog a wnawn yn mynd i ofalu am eich dŵr a'ch amgylchedd. Cysylltwch a ni yn Gymraeg neu'n Saesneg.

Dŵr Cymru Cyf (2366777)
A limited Company registered in Wales
Cwmni cyfyngedig wedi'i gofrestu yng Nghymru:
Linea, Fortran Road, St Mellons, Cardiff, CF3 0LT